NYC 9/11 Public Portal Document

AMBIENTGROUP,INC.

10MorrisAvenue ,GlenCove ,NY11542
Phone: (516)609-0009-Fax: (516)609-8271

LaboratoryReport
AGL01758

AirborneAsbestosFiberAnalysis byTransmissionElectronMicroscopy

Client: Cushman&Wakefield/a/fNewYork
Address: MerchantileExc
1NorthEndAve
NewYork,NY10282

CollectedBy: RobertF.
Collected: 01/31/2002 13:45
Rotometer: Standard

JobNumber: 211338
DateReceived: 02/01/2002
DateAnalyzed: 2/2/02
JobLocation: 1NorthEndAve

LabID / FieldID	SampleLocation	Volume (liters)	Asbestos Type(s)	Asbestos Structures ≥2.5µm <5 µm	Asbestos Structures ≥5µm	Non-Asbestos	Analytical Sensitivity (AS/cc)	Asbestos Concentration (AS/cc)	Asbestos Concentration (AS/mm2)
0001758-001 3685-1	13thFloor:WestsideElev.Lobby	1650	NoneDetected	0	0	0	0.0046	<0.0046	<19.92
0001758-002 3685-2	10thFloor:DiningAreaSouth West	1710	NoneDetected	0	0	0	0.0045	<0.0045	<19.92
0001758-003 3685-3	7thFloor:AdjStair"C"	1650	NoneDetected	0	0	0	0.0046	<0.0046	<19.92
0001758-004 3685-4	3rdFloor:Adj.Stair"D"	1485	NoneDetected	0	0	0	0.0041	<0.0041	<15.94

AverageFilterLoading: 0.000

SIGNEDFORAMBIENTGROUP,INC.BY:

Disclaimers:Thelaboratoryisnotresponsibleforfiberscoun tedinfibers/ccwhichisdependentonvolumecollectedbynon-laboratorypersonnel. Thisreportmaynotbeduplicatedinpartwithoutwrittenpermissi onbyJJResources,Inc.Thisreportmustnotbeusedtocla improductendorsementbyNVLAPoranyagencyoftheU.S.Government.This reportrelatesonlytothesamp eslistedabove.

02/05/02 TUE 11:41 [TX/RX NO 9215]
CITY_21MC100_002860866

NYC-WTC_000366019