NYC 9/11 Public Portal Document

ambient group inc.

Indoor environmental quality surveys
Water treatment consulting
Asbestos & lead field services
Regulatory compliance programs
Air, water & soil analytical laboratories

NATIONAL HEADQUARTERS
55 WEST 39th STREET
12th FLOOR
NEW YORK, NEW YORK 10018
TEL: (212) 463-7812
FAX: (212) 463-9397
WEB: WWW.AMBIENTGROUP.COM

November 20, 2001

Mr. Elliot Zuckerman
Cushman & Wakefield
a/a/f Mercantile Exchange
One North End Avenue
New York, New York 10282

Re: One North End Avenue
Ambient Project # 211338

Dear Mr. Zuckerman:

The following is a summary of the indoor environmental quality survey that Ambient Group, Inc. performed on November 15, 2001 at the above referenced location. The survey included sampling for airborne metals, polynuclear aromatic hydrocarbons and airborne asbestos structures by TEM.

Four (4) air samples were collected from floors 2, 3, 7 and 10 and analyzed for polynuclear aromatic hydrocarbons in air. Analysis of all four (4) samples collected revealed that the levels of the individual compounds were below the OSHA Permissible Exposure Limits and NIOSH REL guidelines.

Four (4) air samples were collected from floors 2, 3, 7 and 10 and analyzed for metals in air (including silica). All measured metals revealed levels well below their respective OSHA PELs and NIOSH RELs.

Please refer to attached laboratory data sheets for further details. Results for the remaining parameters tested will be made available as soon as the analysis is completed. Should you have any questions regarding this information, please feel free to call me.

Sincerely,
Signed for Ambient Group, Inc. by:

John Leitner
Vice President

JL/nt

GLEN COVE, NY 516 609-0009
MIAMI, FL 305 860-0101
CHICAGO, IL 312 527-5526
ORANGE, CA 714 282-2525

CITY_21MC100_002860989

NYC-WTC_000366121