NYC 9/11 Public Portal Document

ambient group inc.

Indoor environmental quality surveys
Water treatment consulting
Asbestos & lead field services
Regulatory compliance programs
Air, water & soil analytical laboratories

NATIONAL HEADQUARTERS

55 WEST 39TH STREET
12TH FLOOR
NEW YORK, NEW YORK 10018
TEL: (212) 463-7872
FAX: (212) 463-9397
WEB: WWW.AMBIENTGROUP.COM

November 16, 2001

Mr. Elliot Zuckerman
Cushman & Wakefield
a/a/f Mercantile Exchange
One North End Avenue
New York, New York 10282

Re: One North End Avenue
Ambient Project # 211338

Dear Mr. Zuckerman:

The following is a summary of the indoor environmental quality survey that Ambient Group, Inc. performed on November 8, 2001 at the above referenced location. The sampling for airborne metals, polynuclear aromatic hydrocarbons and airborne asbestos structures by TEM are summarized below.

Four (4) air samples were collected from various locations on floors 1, 3, 7 and 13 and analyzed by transmission electron microscopy (TEM) for asbestos structures. The results of the analysis indicated that airborne asbestos levels inside and outside the building at the time of testing were less than the analytical sensitivity of the instrument, which is well below the EPA standard of 70 structures/mm^2 as well as other recommended industry guidelines and/or regulations.

Four (4) air samples were collected from floors 1, 3, 7 and 13 and analyzed for metals in air. All measured metals were within their respective OSHA Permissible Exposure Limits.

Four (4) air samples were collected from floors 13, 7, 3 and 1 and analyzed for polynuclear aromatic hydrocarbons in air. Analysis of all four (4) samples collected revealed that the levels of the individual compounds were below the OSHA Permissible Exposure Limits and NIOSH REL guidelines.

Please refer to attached laboratory data sheets for further details. Should you have any questions regarding this information, please feel free to call me.

Sincerely,
Signed for Ambient Group, Inc. by:

for John Leitner

John Leitner,
Vice President

CITY_21MC100_002860999

NYC-WTC_000366131