NYC 9/11 Public Portal Document

ATC Associates Inc.
104 E. 25th St., 10th Floor, New York, NY 10010-2917
(212) 353-8280 Fax (212) 353 8306

Air Samples Phase Contrast Microscopy (PCM) Results

Client Name : Airtek Environmental Corp.
CLient No. : 15495
Project Name : EM&CA/Lions Head Develop.
Project No. : 15495-3041
Project Address: Lions Head Development
110 Church Street, LLC

Page : 1
NLAP No. : 10879
NVLAP No. : 1187
Microscope #: NYC0643
Method : NIOSH 7400/A Rules
Revision #3

Sample No.	Batch No.	Analyzed by	Sample Location			Type	Collect Date	Total Time	Flow Rate	Total Volume	Results
			Work Area	In/Out	Location			Min.	L/Min.	Liters	F/c.c.
01	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	22nd fl, elevator motor room	Final	12/08/01	120	15.00	1800	<0.003
02	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	22nd fl, elevator motor room	Final	12/08/01	120	15.00	1800	<0.003
03	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	22nd fl, elevator motor room	Final	12/08/01	120	15.00	1800	<0.003
04	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	22nd fl, elevator motor room	Final	12/08/01	120	15.00	1800	<0.003
05	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	22nd fl, elevator motor room	Final	12/08/01	120	15.00	1800	<0.003
06	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	2nd fl, N side	Final	12/08/01	120	15.00	1800	<0.003
07	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	2nd fl, N center side	Final	12/08/01	120	15.00	1800	<0.003
08	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	2nd fl, NW side	Final	12/08/01	120	15.00	1800	<0.003
09	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	2nd fl, SE side	Final	12/08/01	120	15.00	1800	<0.003
10	6817	DK	Basement, 1-2 fls, 22 fl	OSWA	2nd fl, S side	Final	12/08/01	120	15.00	1800	<0.003
11	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	1st fl, N center side	Final	12/08/01	120	15.00	1800	<0.003
12	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	1st fl, within 10' from E elevator	Final	12/08/01	120	15.00	1800	<0.003
13	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	1st fl, E elevator bank	Final	12/08/01	120	15.00	1800	<0.003
14	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	1st fl, W elevator bank	Final	12/08/01	130	15.00	1950	<0.003
15	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	1st fl, W side of floor	Final	12/08/01	120	15.00	1800	<0.003
16	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	1st fl, SE side of floor	Final	12/08/01	120	15.00	1800	<0.003
17	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	1st fl, S center side	Final	12/08/01	120	15.00	1800	<0.003
18	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	1st fl, E side	Final	12/08/01	120	15.00	1800	<0.003
19	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	1st fl, E center side	Final	12/08/01	120	15.00	1800	<0.003
20	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	1st fl, hoist motor room	Final	12/08/01	120	15.00	1800	<0.003
21	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	2nd fl, N side	Final	12/08/01	120	15.00	1800	<0.003
22	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	2nd fl, N center side	Final	12/08/01	120	15.00	1800	<0.003
23	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	2nd fl, NW side	Final	12/08/01	120	15.00	1800	<0.003
24	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	2nd fl, SE side	Final	12/08/01	120	15.00	1800	<0.003
25	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	2nd fl, S side	Final	12/08/01	120	15.00	1800	<0.003
26	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	Basement, NW side	Final	12/08/01	120	15.00	1800	<0.003
27	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	Basement, W side	Final	12/08/01	120	15.00	1800	<0.003
28	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	Basement, W side	Final	12/08/01	120	15.00	1800	<0.003

LEGEND
OSWA - Outside Work Area
ISWA - Inside Work Area
Min. - Time in Minutes
c.c. - Cubic Centimeter
L - Liters
F - Fibers
PEL - Permissible Exposure Limit

**Results are in actual Fibers/c.c. or as limit of quantitation whichever is higher.
Note - Action criteria for area samples is 0.01 fibers/c.c.
- For personal samples, PEL(OSHA) is 0.1 fibers/c.c.

Laboratory Director / Approved Signatory

02/27/02 11:01 FAX 1212 588 0830
002
CITY_DEP_WORBY_CANNATA_SUBP_00021071
NYC-WTC_000366223

NYC 9/11 Public Portal Document

ATC Associates Inc.
104 E. 25th St., 10th Floor, New York, NY 10010-2917
(212) 353-8280 Fax (212) 353 8306

Air Samples Phase Contrast Microscopy (PCM) Results

Client Name : Airtek Environmental Corp.
CLient No. : 15495
Project Name : EM&CA/Lions Head Develop.
Project No. : 15495-3041
Project Address: Lions Head Development
110 Church Street, LLC

Page : 2
NLAP No. : 10879
NVLAP No. : 1187
Microscope #: NYC0643
Method : NIOSH 7400 /A Rules
Revision # 3

Sample No.	Batch No.	Analyzed by	Sample Location			Type	Collect Date	Total Time	Flow Rate	Total Volume	Results
			Work Area	In/Out	Location			Min.	L/Min.	Liters	F/c.c.
23	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	Basement, N center side	Final	12/08/01	120	15.00	1800	<0.003
30	6817	DK	Basement, 1-2 fls, 22 fl	ISWA	Basement, N side	Final	12/08/01	120	15.00	1800	<0.003

LEGEND
- OSWA - Outside Work Area
- ISWA - Inside Work Area
- Min. - Time in Minutes
- c.c. - Cubic Centimeter
- L - Liters
- F - Fibers
- PEL - Permissible Exposure Limit

**Results are in actual Fibers/c.c. or as limit of quantitation whichever is higher.
Note - Action criteria for area samples is 0.01 fibers/c.c.
- For personal samples, PEL(OSHA) is 0.1 fibers/c.c.

Laboratory Director / Approved Signatory

02/27/02 11:02 FAX 1212 588 0930

003

CITY_DEP_WORBY_CANNATA_SUBP_00002107

NYC-WTC_000366224