NYC 9/11 Public Portal Document

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306

Attn: Mr. Michael Zovak
Airtek Environmental Corporation
39 W. 38th Sreet
New York , NY 10018

Fax: (212) 768-0759 Phone: (212) 768-0516

Project: Lions Head 110 Development LLC
110-120 Church Street

Received: 12/18/01 10:00:00 AM

ATC Group #: 6141

Analysis Date: 12/18/01

Asbestos Fiber Analysis by Transmissio erformed by EPA 40 CFR Part 7

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures 0.5µ-5	Structures 5µ	A	S		
001 6141 -1	1250.00	0.0674	0	None Detected	0	0				
002 6141 -2	1250.00	0.0674	0	None Detected	0	0				
003 6141 -3	1250.00	0.0674	0	None Detected	0	0				
004 6141 -4	1250.00	0.0674	0	None Detected	0	0	0.0046	<14.83	<0.0046	
005 6141 -5	1250.00	0.0674	0	None Detected	0	0	0.0046	<14.83	<0.0046	
011 6141 -6	1250.00	0.0674	0	None Detected	0	0	0.0046	<14.83	<0.0046	
012 6141 -7	1250.00	0.0674	0	None Detected	0	0	0.0046	<14.83	<0.0046	
013 6141 -8	1250.00	0.0674	0	CHRYSOTILE	2	0	0.0046	29.66	0.0091	

ROMAN PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879