NYC 9/11 Public Portal Document

THE METRO GROUP, INC.
Servicing Water Systems with Environmental Care

CERTIFICATE OF ANALYSIS
METAL SCAN ANALYSIS

MILFORD MANAGEMENT
380 RECTOR PLACE
NEW YORK, NY

ANALYSIS NO.: 8405
DATE: 11/1/01
SAMPLING DATE: 10/18/01

SOURCE OF SAMPLE - WATER FROM APT. 25J, MASTER BEDROOM SHOWER, COLD
Tests Chemical analysis for conformance with Safe Drinking Water Act.

PARAMETER	YOUR RESULT	SAFE DRINKING WATER ACT MAX. CONTAMINANT LEVEL	
Chloride	13.3	250	mg/L
Color	<5 0	15	Units
Conductivity	112		umhos/cm
Fluoride	1 00	2 2	mg/L
Corrosivity (L.S.I.)	-2.24		Units
Nitrate N	0 17	10 0	mg/L
Odor	0	3	Units
pH	6 6	6 5-8.5	Units
Sulfate	6.6	250	mg/L
Total Alkalinity	22 4		mg/L
Total Dissolve Solids	99 0		mg/L
Turbidity	<1.0	5.0	ntu
Arsenic	<3.0	50 0	ug/L
Barium	<0 20	2.0	mg/L
Cadmium	<5.00	5 0	ug/L
Calcium	8 24		mg/L
Chromium	<0 01	10	mg/L
Copper	0 08	1 3	mg/L
Lead	<1.0	15 0	ug/L
Iron	0.02	30	mg/L
Magnesium	2 07		mg/L
Manganese	0.02	0.30	mg/L
Sodium	9.77	250	mg/L
Total Hardness	29 1		mg/L
Zinc	0 02	5 0	mg/L

CODES: MCL (Maximum Contaminant Level), mg/L (milligrams/liter - ppm), * indicates analyte exceeds EPA/SDWA proposed maximum contamination level.

COMMENTS: ALL PARAMETERS FALL WITHIN THE MAXIMUM CONTAMINANT LEVELS STIPULATED FOR A SAFE DRINKING WATER.

JD'gn

Jackie Durgahzadeh
LABORATORY MANAGER

Responsible Care®

NOV 02 01 11:01a

CITY_21MC100_002850461

NYC-WTC_000367019