NYC 9/11 Public Portal Document

JLC ENVIRONMENTAL CONSULTANTS, INC.
200 Park Avenue South, Suite 1001, New York, New York 10003
Phone. (212) 420-6119 Fax (212) 420-6092

Project No.. 01-2104
Analyte FIBERS
Date Received 9/25/01
Date Analyzed: 9/25/01
Batch #: 0109A655

Cooper Square Realty
6 East 43rd Street
New York, NY 10017

F AP Lab Code: 1029
NIO [illegible] AIHA Lab Code. 100273
NVLAP Lab Code: 101953

SUMMARY OF ANALYTICAL RESULTS

Site: *2 South End Avenue, New York, NY*

SAMPLE # COLLECTED LAB #	DESCRIPTION / LOCATION	TIME(min)	VOLUME(l)	FIB/FIELD	RESULTS(f/cc)
001 24-September A 6468	Ambient/ 9th Floor/ Hallway	120	1847	30/100	0.008
002 24-September A 6469	Ambient/ 9th Floor/ Apartment #9AB	120	1847	26/100	0.007
003 24-September A 6470	Ambient/ 9th Floor/ Apartment #9K	120	1847	9/100	0.002
004 24-September A 6471	Ambient/ 8th Floor/ Hallway	120	1847	7/100	0.002
005 24-September A 6472	Ambient/ 8th Floor/ Apartment #8G	120	1847	2/100	<0.001<LOD
006 24-September A 6473	Ambient/ 8th Floor/ Apartment #8M	120	1847	2/100	<0.001<LOD

Sample Analysis by
Positive Phase Contrast Microscopy (PCM)

<LOD = Less than limit of detection which is 5.5 Fibers/ 100 Fields
VOID1 = HCP (High Concentration of Particles)
VOID2 = Overloaded

Method of Sample Preparation and Analysis:
All samples analyzed in accordance with the NIOSH 7400 Method using "A" Counting Rules Issue 2, August 1994

Instrumentation:
Olympus PCM Model BH-2 with Walton-Beckett Graticule (100um field diameter)

Al Wallner
Laboratory Director

Report Date: September 25, 2001

JLC is responsible for only the fiber counts within the limitations of the method described as NIOSH 7400. Among other limitations, this method gives only an index of airborne fibers and provides only an estimate of asbestos concentration. Any and all claims arising out of JLC's analysis of these samples are limited in recovery to the cost of analyzing samples. JLC accepts no other liability and the client agrees to seek no costs beyond the above.

CITY_21MC100_002861824

NYC-WTC_000367187

NYC 9/11 Public Portal Document

JLC ENVIRONMENTAL CONSULTANTS, INC.
200 Park Avenue South Suite 1001, New York, New York 10003
Phone (212) 420-8119 Fax (212) 420-6092

Cooper Square Realty
6 East 43rd Street
New York, NY 10017

ELAP Lab Code: 11029
NIOSH and AIHA Lab Code: 100273
NVLAP Lab Code 101953

Project No.: 01-2104
Analyte: FIBERS
Date Received: 9/25/01
Date Analyzed: 9/25/01
Batch #: 0109A655

SUMMARY OF ANALYTICAL RESULTS

Site: 2 South End Avenue, New York, NY

SAMPLE # COLLECTED LAB #	DESCRIPTION / LOCATION	TIME(min)	VOLUME(l)	FIB/FIELD	RESULTS(f/cc)
007 24-September A 6474	Ambient/ 8th Floor/ Apartment #8U	120	1847	2/100	<0 001<LOD
008 24-September A 6475	Ambient/ 7th Floor/ Hallway	120	1847	2/100	<0.001<LOD
009 24-September A 6476	Ambient/ 7th Floor/ Apartment #7J	120	1847	3/100	<0 001<LOD
010 24-September A 6477	Ambient/ 7th Floor/ Apartment #7P	120	1847	6/100	0 002
011 24-September A 6478	Ambient/ 7th Floor/ Apartment #7U	120	1847	3/100	<0.001<LOD
012 24-September A 6479	Ambient/ 6th Floor/ Apartment #6S	120	1847	3/100	<0 001<LOD

Sample Analysis by
Positive Phase Contrast Microscopy (PCM)

<LOD = Less than limit of detection which is 5 5 Fibers/ 100 Fields
VOID1 = Heavy Particulate (High Concentration of Particles)
VOID2 = Overloaded

Method of Sample Preparation and Analysis
All samples analyzed in accordance with the NIOSH 7400 Method using "A" Counting Rules, Issue 2, August 1994

Instrumentation.
Olympus PCM Model BH-2 with Walton-Beckett Graticule (100um field diameter)

Al Wallner
Laboratory Director

Report Date: September 25, 2001

JLC is responsible for only the fiber counts within the limitations of the method described as NIOSH 7400. Among other limitations, this method gives only an index of airborne fibers and provides only an estimate of asbestos concentration. Any and all claims arising out of JLC's analysis of these samples are limited in recovery to the cost of analyzing samples. JLC accepts no other liability and the client agrees to seek no costs beyond the above

CITY_21MC100_002861825

NYC-WTC_000367188

NYC 9/11 Public Portal Document

JLC ENVIRONMENTAL CONSULTANTS, INC.
200 Park Avenue South Suite 1001 New York, New York 10003
Phone (212) 420-0119 Fax (212) 420-6092

Cooper Square Realty
6 East 43rd Street
New York, NY 10017

ELAP Lab Code 11029
NIOSH Lab Code: 100273
NVLAP Lab Code 101953

Project No 01-2104
Analyte FIBERS
Date Received 9/25/01
Date Analyzed: 9/25/01
Batch #: 0109A666

SUMMARY OF ANALYTICAL RESULTS

Site: 2 South End Avenue, New York, NY

SAMPLE # COLLECTED LAB #	DESCRIPTION / LOCATION	TIME(min)	VOLUME(l)	FIB/FIELD	RESULTS(f/cc)
013 24-September A 6480	Ambient/ 6th Floor/ Apartment #6R	120	1847	2/100	<0 001<LOD
014 24-September A 6481	Ambient/ 6th Floor/ Hallway	120	1847	3/100	<0 001<LOD
015 24-September A 6482	Ambient/ 6th Floor/ Apartment #6C	120	1847	2/100	<0 001<LOD
016 24-September A 6483	Ambient/ 5th Floor/ Hallway	120	1847	2/100	<0.001<LOD
017 24-September A 6484	Ambient/ 5th Floor/ Apartment #5I	120	1847	2/100	<0 001<LOD
018 24-September A 6485	Ambient/ 5th Floor/ Apartment #5J	120	1847	3/100	<0 001<LOD

Sample Analysis by:
Positive Phase Contrast Microscopy (PCM)

<LOD = Less than limit of detection which is 5 5 Fibers/ 100 Fields
VOID1 = H O P (High Concentration of Particles)
VOID2 = Overloaded

Method of Sample Preparation and Analysis.
All samples analyzed in accordance with the NIOSH 7400 Method using "A" Counting Rules Issue 2, August 1994

Instrumentation
Olympus PCM Model BH-2 with Walton Beckett Graticule (100um field diameter)

Al Wallner
Laboratory Director

Report Date: September 25, 2001

JLC is responsible for only the fiber counts within the limitations of the method described as NIOSH 7400 Among other limitations, this method gives only an index of airborne fibers and provides only an estimate of asbestos concentration. Any and all claims arising out of JLC's analysis of these samples are limited in recovery to the cost of analyzing samples JLC accepts no other liability and the client agrees to seek no costs beyond the above

CITY_21MC100_002861826

NYC-WTC_000367189

NYC 9/11 Public Portal Document

JLC ENVIRONMENTAL CONSULTANTS, INC.
200 Park Avenue South Suite 1001, New York, New York 10003
Phone. (212) 420-8119 Fax (212) 420-6092

Project No. 01-2104
Analyte: FIBERS
Date Received 9/25/01
Date Analyzed 9/25/01
Batch #: 0109A668

Cooper Square Realty
6 East 43rd Street
New York, NY 10017

ELAP Lab Code: 11029
NIOSH and AIHA Lab Code: 100273
NVLAP Lab Code. 101953

SUMMARY OF ANALYTICAL RESULTS

Site: *2 South End Avenue, New York, NY*

SAMPLE # COLLECTED LAB #	DESCRIPTION / LOCATION	TIME(min)	VOLUME(l)	FIB/FIELD	RESULTS(f/cc)
019 24-September A 6486	Ambient/ 5th Floor/ Apartment #5N	120	1847	4/100	0.001<LOD
020 24-September A 6487	Ambient/ 4th Floor/ Apartment #4J	120	1847	2/100	<0.001<LOD
021 24-September A 6488	Ambient/ 4th Floor/ Apartment #4A	120	1847	3/100	<0.001<LOD
022 24-September A 6489	Ambient/ 4th Floor/ Apartment #4W	120	1847	8/100	0.002
023 24-September A 6490	Ambient/ 4th Floor/ Hallway	120	1847	2/100	<0.001<LOD
024 24-September A 6491	Ambient/ 3rd Floor/ Apartment #3K	120	1847	2/100	<0.001<LOD

Sample Analysis by:
Positive Phase Contrast Microscopy (PCM)

<LOD = Less than limit of detection which is 5.5 Fibers/ 100 Fields
VOID1 = HOP (High Concentration of Particles)
VOID2 = Overloaded

Method of Sample Preparation and Analysis:
All samples analyzed in accordance with the NIOSH 7400 Method using "A" Counting Rules. Issue 2, August 1994

Instrumentation:
Olympus PCM Model BH-2 with Walton-Beckett Graticule (100um field diameter).

Al Wallner
Laboratory Director

Report Date. September 25, 2001

JLC is responsible for only the fiber counts within the limitations of the method described as NIOSH 7400. Among other limitations, this method gives only an index of airborne fibers and provides only an estimate of asbestos concentration. Any and all claims arising out of JLC's analysis of these samples are limited in recovery to the cost of analyzing samples. JLC accepts no other liability and the client agrees to seek no costs beyond the above

CITY_21MC100_002861827

NYC-WTC_000367190

NYC 9/11 Public Portal Document

JLC ENVIRONMENTAL CONSULTANTS, INC.
200 Park Avenue South, Suite 1001 New York, New York 10003
Phone: (212) 420-5119 Fax: (212) 420-6092

Cooper Square Realty
6 East 43rd Street
New York, NY 10017

ELAP Lab Code 11029
NIOSH and AIHA Lab Code 100273
NVLAP Lab Code 101953

Project No.. 01-2104
Analyte FIBERS
Date Received: 9/25/01
Date Analyzed 9/25/01
Batch #: 0109A666

SUMMARY OF ANALYTICAL RESULTS

Site: 2 South End Avenue, New York, NY

SAMPLE # COLLECTED LAB #	DESCRIPTION / LOCATION	TIME(min)	VOLUME(l)	FIB/FIELD	RESULTS(f/cc)
025 24-September A 6492	Ambient/ 3rd Floor/ Apartment #3G	120	1847	2/100	<0.001<LOD
026 24-September A 6493	Ambient/ 3rd Floor/ Apartment #3E	120	1847	2/100	<0.001<LOD
027 24-September A 6494	Ambient/ 3rd Floor/ Hallway	120	1847	9/100	0.002
028 24-September A 6495	Ambient/ 2nd Floor/ Apartment #2F	120	1847	3/100	<0.001<LOD
029 24-September A 6496	Ambient/ 2nd Floor/ Apartment #2A	120	1847	2/100	<0.001<LOD
030 24-September A 6497	Ambient/ 2nd Floor/ North Side/ Town House #3	120	1847	2/100	<0.001<LOD

Sample Analysis by:
Positive Phase Contrast Microscopy (PCM)

<LOD = Less than limit of detection which is 5.5 Fibers/ 100 Fields
VOID1 = Heavy (High Concentration of Particles)
VOID2 = Overloaded

Method of Sample Preparation and Analysis:
All samples analyzed in accordance with the NIOSH 7400 Method using "A" Counting Rules Issue 2, August 1994

Instrumentation:
Olympus PCM Model BH-2 with Walton-Beckett Graticule (100um field diameter)

Al Wallner
Laboratory Director

Report Date: September 25, 2001

JLC is responsible for only the fiber counts within the limitations of the method described as NIOSH 7400. Among other limitations, this method gives only an index of airborne fibers and provides only an estimate of asbestos concentration. Any and all claims arising out of JLC's analysis of these samples are limited in recovery to the cost of analyzing samples. JLC accepts no other liability and the client agrees to seek no costs beyond the above.

CITY_21MC100_002861828

NYC-WTC_000367191

NYC 9/11 Public Portal Document

JLC ENVIRONMENTAL CONSULTANTS, INC
200 Park Avenue South, Suite 1001 New York, New York 10003
Phone (212) 420-6119 Fax (212) 420-6092

Cooper Square Realty
6 East 43rd Street
New York, NY 10017

ELAP Lab Code 1029
NIOSH and AIHA Lab Code 100273
NVLAP Lab Code 101955

Project No : 01-2104
Analyte: FIBERS
Date Received 9/25/01
Date Analyzed. 9/25/01
Batch #: 0109A655

SUMMARY OF ANALYTICAL RESULTS

Site: *2 South End Avenue, New York, NY*

SAMPLE # COLLECTED LAB #	DESCRIPTION / LOCATION	TIME(min)	VOLUME(l)	FIB/FIELD	RESULTS(f/cc)
031 24-September A 6498	Ambient/ 2nd Floor/ North Side/ Hallway	120	1847	3/100	<0.001<LOD
032 24-September A 6499	Ambient/ Lobby	120	1847	4/100	0.001<LOD
033 24-September A 6500	Ambient/ Lobby	120	1847	4/100	0.001<LOD
034 24-September A 6501	FIELD BLANK			0/100	
035 24-September A 6502	FIELD BLANK			0/100	
036 24-September A 6503	FIELD BLANK			0/100	

Sample Analysis by:
Positive Phase Contrast Microscopy (PCM)

<LOD = Less than limit of detection which is 5.5 Fibers/ 100 Fields
VOID1 = High Particle (High Concentration of Particles)
VOID2 = Overloaded

Method of Sample Preparation and Analysis
All samples analyzed in accordance with the NIOSH 7400 Method using "A" Counting Rules Issue 2, August 1994

Instrumentation:
Olympus PCM Model BH-2 with Walton-Beckett Graticule (100um field diameter)

Al Wallner
Laboratory Director

Report Date September 25, 2001

JLC is responsible for only the fiber counts within the limitations of the method described as NIOSH 7400. Among other limitations, this method gives only an index of airborne fibers and provides only an estimate of asbestos concentration. Any and all claims arising out of JLC's analysis of these samples are limited in recovery to the cost of analyzing samples. JLC accepts no other liability and the client agrees to seek no costs beyond the above.

CITY_21MC100_002861829

NYC-WTC_000367192