NYC 9/11 Public Portal Document

THE METRO GROUP, INC.
Servicing Water Systems with Environmental Care

50-23 Twenty-Third Street
Long Island City, NY 11101
TEL: (718) 729-7200
FAX: (718) 729-8677

CERTIFICATE OF ANALYSIS
METAL SCAN ANALYSIS

BROWN HARRIS STEVENS
NEW YORK, NY

ANALYSIS NO.: 8371-1
DATE: 10/15/01
SAMPLING DATE: 9/26/01

SOURCE OF SAMPLE – WATER FROM 21 SOUTH END AVE. - MAIN
Tests: Chemical analysis for conformance with Safe Drinking Water Act.

PARAMETER	YOUR RESULT	SAFE DRINKING WATER ACT MAX. CONTAMINANT LEVEL	
Chloride	15.2	250	mg/L
Color	10.0	15	Units
Conductivity	120		umhos/cm
Fluoride	0.84	2.2	mg/L
Corrosivity (L.S.I.)	-2.20		Units
Nitrate N	0.27	10.0	mg/L
Odor	0	3	Units
pH	7.0	6.5-8.5	Units
Sulfate	8.3	250	mg/L
Total Alkalinity	22.1		mg/L
Total Dissolve Solids	108		mg/L
Turbidity	<1.0	5 0	ntu
Arsenic	<3.0	50.0	ug/L
Barium	<0.20	2.0	mg/L
Cadmium	<5.0	5.0	ug/L
Calcium	8.66		mg/L
Chromium	<0.01	1.0	mg/L
Copper	<0.02	1.3	mg/L
Lead	<1.0	15.0	ug/L
Iron	0.04	.30	mg/L
Magnesium	2.19		mg/L
Manganese	0.03	0.30	mg/L
Sodium	11.0	250.	mg/L
Total Hardness	30.6		mg/L
Zinc	<0.02	5.0	mg/L

CODES: MCL (Maximum Contaminant Level), mg/L (milligrams/liter - ppm), * indicates analyte exceeds EPA/SDWA proposed maximum contamination level.

COMMENTS: ALL PARAMETERS FALL WITHIN THE MAXIMUM CONTAMINANT LEVELS STIPULATED FOR A SAFE DRINKING WATER.

JD.gn

Jackie Darvishzadeh
LABORATORY MANAGER

Responsible Care®
Good Chemistry at Work

NYC-WTC_000367199