NYC 9/11 Public Portal Document

2ND TEST

Attn: Tom

THE METRO GROUP, INC.
Servicing Water Systems with Environmental Care
[redacted]

CERTIFICATE OF ANALYSIS

METAL SCAN ANALYSIS

BROWN HARRIS STEVENS
21 SOUTH END AVE.
NEW YORK, NY

ANALYSIS NO.: 8385-4
DATE: 10/26/01
SAMPLING DATE: 10/5/01

SOURCE OF SAMPLE – WATER FROM COLD – LOBBY BATHROOM
Tests: Chemical analysis for conformance with Safe Drinking Water Act.

PARAMETER	YOUR RESULT	SAFE DRINKING WATER ACT MAX. CONTAMINANT LEVEL	
Chloride	12.8	250	mg/L
Color	<5.0	15	Units
Conductivity	113		umhos/cm
Fluoride	0.95	2.2	mg/L
Corrosivity (L.S.I.)	-2.58		Units
Nitrate N	0.19	10.0	mg/L
Odor	0	3	Units
pH	6.7	6.5-8.5	Units
Sulfate	5.7	250	mg/L
Total Alkalinity	20.7		mg/L
Total Dissolve Solids	102		mg/L
Turbidity	<1.0	5.0	ntu
Arsenic	<3.0	50.0	ug/L
Barium	<0.20	2.0	mg/L
Cadmium	<3.00	5.0	ug/L
Calcium	7.51		mg/L
Chromium	<0.01	.10	mg/L
Copper	<0.10	1.3	mg/L
Lead	<1.0	15.0	ug/L
Iron	0.03	.30	mg/L
Magnesium	1.80		mg/L
Manganese	0.02	0.30	mg/L
Sodium	9.06	250.	mg/L
Total Hardness	26.2		mg/L
Zinc	<0.02	5.0	mg/L

CODES: MCL (Maximum Contaminant Level), mg/L (milligrams/liter - ppm), * indicates analyte exceeds EPA/SDWA proposed maximum contamination level.

COMMENTS: ALL PARAMETERS FALL WITHIN THE MAXIMUM CONTAMINANT LEVELS STIPULATED FOR A SAFE DRINKING WATER.

JD:gn

Jackie Darvishzadeh
LABORATORY MANAGER

Responsible Care
Total Commitment at Work

NYC-WTC_000367205