NYC 9/11 Public Portal Document

ATC ASSOCIATES INC

New York New York 10010
www.atc-enviro.com
212 353 8280
Fax 212 353 8306

November 29, 2001

ALC Environmental
115 W 30th Street
New York, NY 10001
Attn. Mr Joshua Sarett

Re: Report of TEM Analysis

Dear Mr. Sarett

Following are the results of transmission electron microscopy (TEM) analysis of air samples from our Group No 5990.

Client Gateway Plaza Mngt Corp
Project Name Building 100 at Gateway Plaza - 345 South End Ave
Location 5th Floor
Samples received: 11/29/01

These results will confirm and document the data transmitted today to you. The analyses were performed in strict conformance with the methodology of the AHERA Final Rule (CFR October 30, 1987) for clearance of abatement sites. The results are as indicated on the attached document

Results reported as Struct/cc are a function of air volume collected in the field and are, as such, not verifiable by this laboratory This report may be reproduced only in its entirety and not without prior permission of this laboratory If the post-abatement inside samples pass, the response action may be considered to have been completed The analyses were supervised by Dr. Michael A. Gorycki, Director of Electron Microscopy.

We are pleased to note that our TEM lab has received <u>full accreditation</u> from NVLAP, as is currently required for recognized analysis of TEM air samples for AHERA projects, and also approval under the NY State DOH ELAP program. These analyses were performed by ATC d/b/a ATC Associates Inc.

Please contact me regarding any questions relating to these materials.

Very truly yours,

Michael A. Gorycki, Ph.D.
Director of Electron Microscopy

CITY_DEP_WORBY_CANNATA_SUBP_000004085

NYC-WTC_000367271