NYC 9/11 Public Portal Document

ATC Associates
104 East 25 Street, New York, NY 10010
Phone (212) 353-8280 Fax: (212) 353-8306

Attn: Mr Joshua Saren
ALC Environmental
115 W 30th Street
New York NY 10001
Fax: (212) 279-6747 **Phone:** (212) 279-1001

Project: Gateway Plaza Management
385 Southerd Ave , Bldg 500 , 5th Floor , NY, NY

Received: 11/19/01 6 00.00 PM
ATC Group #: 5929
Analysis Date: 11/21/01

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	Structures 0.5µ-5	Structures 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
1 5929 -1	1800 00	0.0450	0	None Detected	0	0	0 0048	<22 24	<0 0048	
2 5929 -2	1800 00	0 0450	0	None Detected	0	0	0 0048	<22 24	<0 0048	
3 5929 -3	1800 00	0 0450	0	None Detected	0	0	0 0048	<22 24	<0 0048	
4 5929 -4	1800 00	0 0450	0	None Detected	0	0	0 0048	<22 24	<0 0048	
5 5929 -5	1800 00	0 0450	0	None Detected	0	0	0 0048	<22 24	<0 0048	
6 5929 -6	1800 00	0 0450	0	None Detected	0	0	0.0048	<22 24	<0 0048	

ROMAN PEYSAKHOV
Analyzed by RRuy

MICHAEL A GORYCKI, Ph D
Approved by

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel This lab is only responsible for data reported in structures/mm² This report may not be reproduced except in full, without written approval by ATC Associates Inc This report may not be used to claim product endorsement by NVLAP or any other agency of the U S Government. This reports relates only to the samples reported above Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request

Accredited for NVLAP PLM/TEM #101187-0 NY State ELAP #10879

NYC-WTC_000367285