NYC 9/11 Public Portal Document

ATC Associates
104 East 25 Street, New York, NY 10010
Phone: (212) 353-8280 Fax: (212) 353-8306

Attn: Mr. Joshua Sarett
ALC Environmental
115 W. 30th Street
New York NY 10001
Fax: (212) 279-6747 Phone: (212) 279-1001

Project: Gateway Plaza Management
375 Southerd Ave., Bldg. 600, 12th Floor, NY, NY

Received: 3/13/02 3:00:00 PM
ATC Group #: 7056
Analysis Date: 3/13/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5	# Structures 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
03 7056 -1	2400 00	0 0450	0	None Detected	0	0	0.0036	<22.24	<0.0036	
04 7056 -2	2400.00	0.0450	0	None Detected	0	0	0.0036	<22.24	<0.0036	
05 7056 -3	2400.00	0.0450	0	None Detected	0	0	0.0036	<22.24	<0.0036	
06 7056 -4	2400.00	0.0450	0	None Detected	0	0	0 0036	<22.24	<0 0036	
07 7056 -5	2400.00	0.0450	0	None Detected	0	0	0.0036	<22.24	<0.0036	
08 7056 -6	2400.00	0.0450	0	None Detected	0	0	0.0036	<22.24	<0.0036	
09 7056 -7	2400.00	0.0450	0	None Detected	0	0	0.0036	<22.24	<0.0036	

ROMAN PEYSAKHOV
Analyzed by: RPey

MICHAEL A. GORYCKI, Ph D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_002850568

NYC-WTC_000367403

NYC 9/11 Public Portal Document

Attn: Mr. Joshua Sarett
ALC Environmental
115 W. 30th Street
New York NY 10001
Fax: (212) 279-6747 Phone: (212) 279-1001

Project: Gateway Plaza Management
375 Southerd Ave., Bldg 600, 12th Floor, NY, NY

Received: 3/13/02 3:00:00 PM
ATC Group #: 7056
Analysis Date: 3/13/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures 0.5μ-5	# Structures 5μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
10 7056 -8	2400 00	0.0450	0	None Detected	0	0	0.0036	<22 24	<0.0036	
11 7056 -9	2400 00	0.0450	0	None Detected	0	0	0.0036	<22.24	<0.0036	
12 7056 -10	2400.00	0.0450	0	None Detected	0	0	0.0036	<22.24	<0.0036	

ROMAN PEYSAKHOV
Analyzed by: RRy

MICHAEL A. GORYCKI, Ph.D
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_002850569

NYC-WTC_000367404