NYC 9/11 Public Portal Document

ENVIROSCIENCE CONSULTANTS, INC.

2150 SMITHTOWN AVENUE
RONKONKOMA, NY 11779
PHONE: (631) 580-3191 • FACSIMILE: (631) 580-3195
WWW.ENVIROHEALTH.ORG

ASBESTOS BULK SAMPLE RESULTS

CLIENT:	AMERICAN STOCK EXCHANGE	CHAIN OF CUSTODY:	B-23-26
PROJECT:	ROOF MATERIAL 86 TRINITY 22 THAMES TOP OF TRADE FLOOR	SAMPLER: DATE:	L. SAVARESE JANUARY 31, 2002
PAGE:	1 OF 1	DATE ANALYZED:	FEBRUARY 1, 2002

SAMPLE #	DESCRIPTION / LOCATION	RESULT
2-1	22 Thames, North	**1.8 % Chrysotile**
2-2	22 Thames, Southeast	None Detected
2-3	22 Thames, Southeast	None Detected
2-4	22 Thames, Northwest	None Detected
2-5	22 Thames, West	None Detected
2-6	22 Thames, East	None Detected
2-7	22 Thames, South	None Detected

Reviewed by: Analyzed by:

Asbestos Containing Materials contain more than 1% asbestos (shown in **bold** type).

Trace - Asbestos found is 1% or less; not considered ACM.

None Detected - No asbestos found in samples using polarized light microscopy (PLM).

None Detected by TEM - No asbestos found in samples using transmission electron microscopy (TEM).

Inconclusive - No asbestos found in non friable organically bound samples using polarized light microscopy (PLM).

ELAP # 11681

NYC-WTC_000367449