NYC 9/11 Public Portal Document

ambient group inc.

Indoor environmental quality surveys
Water treatment consulting
Asbestos & lead field services
Regulatory compliance programs
Air, water & soil analytical laboratories

NATIONAL HEADQUARTERS
55 WEST 39TH STREET
12TH FLOOR
NEW YORK, NEW YORK 10018
TEL: (212) 463-7812
FAX: (212) 463-9397
WEB: WWW.AMBIENTGROUP.COM

October 8, 2001

Mr. Steve Stiles
LVI
462 Getty Avenue
Clifton, New Jersey 07011

**Re: 22 Thames Street, New York City**
**Ambient Project # 211464**

Dear Mr. Stiles:

The following is a summary of the indoor environmental quality survey that Ambient Group, Inc. performed on October 7, 2001 at the above referenced location. The survey included sampling for airborne dust characterization and air sample collection for TEM analysis, as well as absence/presence of asbestos in settled dust.

Three (3) air samples were collected from various locations on the 9th floor and analyzed by transmission electron microscopy (TEM) for asbestos structures. The results of the analysis indicated that airborne asbestos levels at the time of testing were well below the EPA standard of 70 structures/mm$^2$ and other recommended industry guidelines and/or regulations.

Six (6) settled dust samples were collected from various locations on the 9th floor and analyzed for the absence/presence of asbestos. All six (6) settled dust samples collected from the carpet and furniture tops tested negative for the presence of asbestos. Other constituents found in these settled dust samples are all items found in New York City commercial office buildings.

Should you have any questions regarding this information, please feel free to call me.

Sincerely,
Signed for Ambient Group, Inc. by:

Neetha Jiwani for

John P. Springston, CIH, CSP
Director of Field Operations