ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 1400

LOCATION PS234M DATE 5/14/02 PROJECT NO. 19125-0279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m³)	TVOCs (ppm)
Outside							
AM Reading Main Entrance		53.5	44.8	388	0	18	[illegible]
AM Reading In by Main Desk		68.3	41.3	426	0	11	[illegible]
South		60.[illegible]	36.3	3[illegible]5	0	25	[illegible]
SE		57.8	36.0	338	0	20	[illegible]
Main Entrance		59.6	35.8	340	0	24	[illegible]
NE		59.3	35.5	337	0	27	[illegible]
Courtyard		59.7	35.1	334	0	25	[illegible]
NW		60.0	34.8	336	0	28	[illegible]
West		59.7	34.7	330	0	27	[illegible]
SW		59.5	34.6	332	0	25	[illegible]
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: [signature] Date: 5/14/02

CITY_21MC100_002851947

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 1930

LOCATION PS 234 M DATE 5/14/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m³)	TVOCs (ppm)
301	1	76.3	27.8	6[illegible]	1	16	[illegible]
[illegible]		77.6	28.[illegible]	69[illegible]	1	[illegible]	[illegible]
[illegible]		76.9	29.9	711	1	8	[illegible]
30[illegible]	28	76.4	31.5	946	1	[illegible]	[illegible]
30[illegible]	1	76.5	31.6	775	1	14	[illegible]
31[illegible]	17	76.2	3[illegible]	733	1	[illegible]	[illegible]
30[illegible]	2	74.8	29.5	692	1	[illegible]	[illegible]
315	3[illegible]	75.2	29.2	714	1	[illegible]	[illegible]
Elevator (main)		74.7	28.5	634	1	14	[illegible]
30[illegible]	22	74.6	28.6	714	1	27	[illegible]
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: [signature] Date: 5/14/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 1500

LOCATION PS234M DATE 5/14/02 PROJECT NO. 19125-0279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m³)	TVOCs (ppm)
319	17	74.7	29.9	672	1	13	[illegible]
323	23	75.2	32.1	800	1	20	[illegible]
[illegible] 1 (hall)		74.8	29.5	680	1	20	[illegible]
310 (hall)		74.7	28.5	579	1	21	[illegible]
325	25	74.9	32.7	862	1	17	[illegible]
320		74.3	31.3	688	1	12	[illegible]
312 (hall)		73.6	30.2	651	1	24	[illegible]
316	25	72.4	27.7	617	1	[illegible]	[illegible]
318	21	72.7	31.9	921	1	32	[illegible]
320	22	71.9	33.5	939	1	31	[illegible]
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: [signature] Date: 5/14/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 1530

LOCATION PS234M DATE 5/14/02 PROJECT NO. 19125-0279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m³)	TVOCs (ppm)
[illegible]	20	72.1	[illegible]	1016	1	[illegible]	[illegible]
[illegible]		72.0	32.7	[illegible]	1	[illegible]	[illegible]
[illegible]	[illegible]	72.3	[illegible]	920	1	[illegible]	[illegible]
[illegible]		73.1	37.9	721	1	13	[illegible]
[illegible]		73.7	[illegible]	726	1	[illegible]	[illegible]
[illegible]		74.3	37.9	743	1	[illegible]	[illegible]
[illegible]		74.0	36.8	761	1	13	[illegible]
[illegible]		74.1	35.0	796	1	14	[illegible]
[illegible]		74.2	33.2	690	1	16	[illegible]
[illegible] (HALL)		74.5	33.0	614	1	14	[illegible]
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: [signature] **Date:** 5/14/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME [illegible]

LOCATION PS234M DATE 5/14/02 PROJECT NO. 19125-0279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m³)	TVOCs (ppm)
[illegible]		75.0	34.0	640	1	16	[illegible]
[illegible]		75.0	35.0	643	1	[illegible]	
[illegible]		74.9	32.6	648	1	[illegible]	
[illegible]		75.0	31.6	600	1	[illegible]	[illegible]
[illegible]		75.6	33.3	616	1	[illegible]	[illegible]
206 (Hall)		75.4	31.8	570	1	18	[illegible]
201		75.7	32.0	576	1	13	[illegible]
203 (Hall)		75.8	31.8	592	1	16	[illegible]
Stair 2 (Hall)		75.0	30.2	560	1	17	[illegible]
Stair #2		75.2	29.7	514	1	[illegible]	[illegible]
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: [signature] Date: 5/14/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 1630

LOCATION PS234M DATE 5/14/02 PROJECT NO. 19125-0279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m³)	TVOCs (ppm)
[illegible]		76.0	29.4	457	1	18	
[illegible]		75.5	28.4	400	1	20	[illegible]
Gym		75.1	29.5	436	1	22	[illegible]
108 (hall)		74.6	29.1	481	1	20	[illegible]
[illegible] 1 (hall)		73.9	28.1	472	1	[illegible]	[illegible]
116		73.3	29.0	788	1	22	[illegible]
118		72.6	31.8	698	1	24	[illegible]
120		72.5	31.0	709	1	23	[illegible]
122		72.8	31.3	677	1	20	[illegible]
Stair 3 (hall)		72.6	31.0	668	1	25	[illegible]
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: [signature] **Date:** 5/14/02