NYC 9/11 Public Portal Document


# ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306


**Attn:** Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

**Fax:** (212) 475-4122 **Phone:** (212) 477-8941

**Project:** NYC-BOE PS 234M Project#: 14584-1823
292 Greenwich St., New York, NY

**Received:** 6/19/02 10:30:00 PM
**ATC Group #:** 8182
**Analysis Date:** 6/20/02

## Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

| Sample | Volume | Area Analyzed | Non Asb | Asbestos Type(s) | # Structures 0.5μ-5 | # Structures 5μ | Analytical Sensitivity (S/cc) | Asbestos Concentration (S/mm²) | Asbestos Concentration (S/cc) | Notes |
|---|---|---|---|---|---|---|---|---|---|---|
| 01 *8182 -1* | 1928.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0044 | <22.24 | <0.0044 | |
| 02 *8182 -2* | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |
| 03 *8182 -3* | 1928.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0044 | <22.24 | <0.0044 | |
| 04 *8182 -4* | 1928.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0044 | <22.24 | <0.0044 | |
| 05 *8182 -5* | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |
| 06 *8182 -6* | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |
| 07 *8182 -7* | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |

ROMAN PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879



CITY_21MC100_002870966

NYC-WTC_000375231

NYC 9/11 Public Portal Document

**Attn:** Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101
**Fax:** (212) 475-4122 **Phone:** (212) 477-8941

**Received:** 6/19/02 10:30:00 PM
**ATC Group #:** 8182
**Analysis Date:** 6/20/02

**Project:** NYC-BOE PS 234M Project#: 14584-1823
292 Greenwich St., New York, NY

## Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

| *Sample* | *Volume* | *Area Analyzed* | *Non Asb* | *Asbestos Type(s)* | *# Structures 0.5μ-5* | *5μ* | *Analytical Sensitivity (S/cc)* | *Asbestos Concentration (S/mm²)* | *(S/cc)* | *Notes* |
|---|---|---|---|---|---|---|---|---|---|---|
| 08 *8182 -8* | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |
| 09 *8182 -9* | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |
| 10 *8182 -10* | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |
| 11 *8182 -11* | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |
| 12 *8182 -12* | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |
| 13 *8182 -13* | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |
| 14 *8182 -14* | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |
| 15 *8182 -15* | 1920.00 | 0.0450 | 0 | None Detected | 0 | 0 | 0.0045 | <22.24 | <0.0045 | |

ROMAN PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879



CITY_21MC100_002870967

NYC-WTC_000375232