NYC 9/11 Public Portal Document

ATC ASSOCIATES INC.

104 East 25th St
New York, New York 10010
www.atc-enviro.com
212.353.8280
Fax 212.353.8306

February 4, 2002

Mr. Bernard P. Orlan
Director, Environmental Health & Safety
New York City Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101-4008

Re: Indoor Air Quality Assessment
P.S. 150M
334 Greenwich Street
New York, New York 10013
ATC Project No. 15-19125-0289

Dear Mr. Orlan:

ATC Associates Inc. (ATC) is pleased to provide this report of indoor air quality (IAQ) measurements collected on February 2, 2002, at the referenced school. The New York City Board of Education (BOE) requested these measurements to evaluate air quality in the school building prior to re-occupancy.

SCOPE OF WORK

ATC conducted this evaluation to assess the basic parameters of temperature, relative humidity, carbon dioxide (CO_2) and carbon monoxide (CO).

ATC measured temperature, relative humidity, CO_2 and CO with a Q-Trak® Model 8551, manufactured by TSI, Inc.

ATC measured concentrations of respirable particulates ($PM_{2.5}$) with a Dust-Trak® Aerosol Monitor Model 8520, manufactured by TSI, Inc.

ATC measured concentrations of Total Volatile Organic Compounds (TVOCs) using a RAE Systems, Inc. MiniRAE® photoionization detector (PID).

Mr. Tim Amstislavskiy, Environmental Technician of ATC's New York City office, conducted the assessment.

ATC's findings are based on a visual inspection, real-time environmental measurements and conditions present in the school at the time of the assessment.

NYC-WTC_000375445

NYC 9/11 Public Portal Document

The assessment was performed consistent with generally accepted indoor air quality assessment practices. As with all such assessments, there were inherent limitations created by constraints of time, operational and work practice variability, variations in indoor air quality parameters and sampling and analytical accuracy. The results of the sampling represent conditions found on the dates of the survey and may not represent conditions found at other times. The information presented in this report should be used by the BOE as a guide to assess the need for further improvements in current indoor air quality control activities.

EVALUATION CRITERIA

Currently, there are no regulatory standards for indoor air quality in non-industrial buildings, such as offices and schools. For the real-time data collected, ATC uses the commonly accepted guidelines cited in the following publications:

- *Ventilation for Acceptable Indoor Air Quality (ASHRAE 62-1999)*, American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE);
- *Thermal Environmental Conditions for Human Occupancy (ASHRAE 55-1992);*
- *Industrial Hygienists Guide to Indoor Air Quality Investigations* (1993), American Industrial Hygiene Association (AIHA).

Table 1 lists target guidelines for the parameters that ATC evaluated during this investigation. Meeting one, some, or all of the listed values does not assure that acceptable indoor air quality will be achieved at all times.

TABLE 1
TARGET GUIDELINES FOR INDOOR AIR QUALITY PARAMETERS EVALUATED

PARAMETER	TARGET LEVEL	AGENCY OR ORGANIZATION
Carbon Dioxide (CO_2)	<700 parts per million (ppm) above background level	ASHRAE 62
Carbon Monoxide (CO)	9 ppm	ASHRAE 62 (adopted from USEPA NPAAQS)
Respirable Particulates ($PM_{2.5}$)	65 micrograms per cubic meter of air ($\mu g/m^3$) 24-hour average	USEPA NPAAQS
	40 $\mu g/m^3$ 24-hour average	USEPA – Recommendation for children / sensitive individuals
Temperature	Summer: 73-79°F at 50% RH Winter: 68-75°F at 50% RH	ASHRAE 55
Relative Humidity	30 – 60 %	ASHRAE 55
Total Volatile Organic Compounds (TVOC)	1 ppm	AIHA

USEPA = United States Environmental Protection Agency
NPAAQS = National Primary Ambient-Air Quality Standard
AIHA = American Industrial Hygiene Association

NYC-WTC_000375446

NYC 9/11 Public Portal Document

REAL-TIME ENVIRONMENTAL MEASUREMENTS

ATC collected forty (40) sets of real-time environmental measurements consisting of thirty-two (32) inside the school building and eight (8) outdoors. All three floors of the school building were surveyed. Field data sheets are found in the Attachment. Readings began at 8:30 A.M. and concluded at approximately 12:30 P.M. The results are described below.

Temperature

Indoor dry bulb temperature measurements ranged from 69.1°F to 80.5°F. One (1) measurement was above the range of 68 to 75°F (at 50 percent relative humidity) as recommended by the ASHRAE Standard 55-1992 during the heating season (wintertime conditions). The outdoor temperature measurements ranged from 37.5 to 45.5°F.

Relative Humidity

The relative humidity indoors ranged from 14.6 to 22.3 percent. All of the measurements were below the ASHRAE-recommended range of 30 to 60 percent for occupant comfort. The outdoor relative humidity measurements ranged from 13.2 to 20.3 percent.

Carbon Dioxide Concentration

Carbon dioxide concentrations indoors ranged from 400 ppm to 630 ppm. All CO_2 measurements were below the ASHRAE Standard 62-1999 recommended maximum concentration of <700 ppm above the background level. The maximum outdoor (background) CO_2 concentration was 478 ppm. Therefore, the maximum acceptable level of CO_2 at this location was 1178 ppm (background level + 700 ppm). Levels above the recommended maximum do not indicate a health risk. Carbon dioxide measurements are used as an indicator of available outside makeup air. The primary source of CO_2 indoors is occupant respiration. The school building was not occupied during ATC's assessment.

Carbon Monoxide Concentration

Carbon monoxide concentrations indoors were 0 ppm for the indoor readings. The outdoor CO concentration was 0-1 ppm for all collected readings.

Respirable Particulates ($PM_{2.5}$)

Respirable particulate concentrations* indoors ranged between 4 $\mu g/m^3$ to 33 $\mu g/m^3$. None of the measurements were above the NPAAQS of 65 $\mu g/m^3$ 24-hour average concentration of particulate matter 2.5 micrometers or less in aerodynamic diameter. The average $PM_{2.5}$ concentration for the entire school building was approximately 9 $\mu g/m^3$. The $PM_{2.5}$ average concentration was below the USEPA recommended concentration of 40 $\mu g/m^3$ for sensitive individuals / children. The outdoor respirable particulate concentration measurements ranged from 4 to 6 $\mu g/m^3$ with an average of 5 $\mu g/m^3$.

* The measurements made during this assessment were instantaneous readings, the NPAAQS is a 24-hour average.

NYC-WTC_000375447

NYC 9/11 Public Portal Document

TVOC Concentrations

TVOCs were not detected anywhere inside the building (0.0 ppm). The outdoor TVOC concentration was also 0.0 ppm.

OBSERVATIONS

During this assessment, ATC noted the following:

- There was construction work going on in the plaza;
- The school building was not occupied other than custodial personnel at the time of the assessment;
- No smoke odor was detected in the building

FINDINGS

Based on the real-time measurements, the following findings are presented:

1. Concentrations of $PM_{2.5}$, CO_2, CO and TVOCs were within applicable standards and guidelines;
2. One (1) temperature measurement was above the range of 68 to 75° F (at 50 percent relative humidity) recommended by ASHRAE Standard 55-1992 during the heating season (wintertime conditions);
3. All measurements of relative humidity were below the ASHRAE-recommended range of 30 to 60 percent.

It is our pleasure to provide these indoor air quality services to the New York City Board of Education. If you have any questions about this report, please call (212) 353-8280, extension 261 or 212.

Sincerely,
ATC ASSOCIATES INC.

James R. Cohn, CIH, CSP
Regional Manager
Industrial Hygiene Division

Attachment

NYC-WTC_000375448