NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 1100

LOCATION PS150 M DATE 2/7/02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m³)	TVOCs (ppm)
Outside Main		40.0	44.0	490	0	38	0
West Side		38.8	44.5	499	0	40	0
North Side		37.1	45.0	509	1	44	0
SE Corner		39.1	45.3	507	1	36	0
East Side		39.5	46.0	519	1	40	0
Main Lobby Area	10	75.3	28.0	589	0	36	0
Ed's Rm.	3	75.0	26.9	621	0	33	0
Office.	4	76.0	27.5	744	0	38	0
Hall by Bathrms.	—	76.0	26.3	546	0	39	0
Music Rm.	22	76.1	27.7	1009	0	40	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: Working in the Courtyard by School.

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: [signature] Date: 2/7/02

CITY_21MC100_002853461

NYC-WTC_000375477

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 11:30

LOCATION PS150 M DATE 2/7/02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m³)	TVOCs (ppm)
401	1	76.5	26.7	781	0	26	0
402	38	76.7	26.7	1048	0	26	0
403	21	77.5	27.1	1085	0	28	0
404	26	77.8	28.0	1040	0	28	0
403(HALL)	—	77.5	25.7	740	0	30	0
504	2	75.0	27.0	843	0	18	0
504(HALL)	—	75.2	26.1	700	0	31	0
503	5	75.3	26.2	855	0	30	0
502	21	75.1	27.6	860	0	32	0
501	20	74.1	26.6	919	0	34	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: _____ Date: 2/7/02

CITY_21MC100_002853462

NYC-WTC_000375478

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 13:00

LOCATION PS150 M DATE 2/7/02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m³)	TVOCs (ppm)
Outside Main Entrance.		50.1	35.0	530	0	38	0
SE Corner		49.5	34.9	525	0	40	0
West side.		49.0	34.5	519	0	35	0
North Side		48.7	36.0	508	0	40	0
East Side.		48.0	36.3	499	0	41	0
General Office		70.3	26.4	509	0	35	0
Principal. office		71.0	26.8	519	0	38	0
Music Room	20	72.1	25.8	891	0	31	0
Kitchen	1	74.0	24.9	770	0	37	0
Nurse Rm.	3	74.3	25.3	691	0	32	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: _____ Date: 2/7/02

CITY_21MC100_002853463

NYC-WTC_000375479

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 1330

LOCATION PS150 M DATE 2/7/02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m^3)	TVOCs (ppm)
401	3	75.1	26.0	789	0	30	0
402	20	77.0	26.5	1009	0	28	0
403	18	77.5	27.0	909	0	31	0
404	20	77.0	28.3	1002	0	28	0
401 (HALL)	—	76.8	25.7	802	0	32	0
501	18	75.8	27.0	903	0	28	0
502	20	75.1	26.3	851	0	30	0
503	10	77.1	27.6	809	0	35	0
504	5	75.3	26.6	799	0	30	0
501 (HALL)	—	74.9	25.5	816	0	33	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m^3 24-hour average	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: _____ Date: 2/7/02

CITY_21MC100_002853464

NYC-WTC_000375480