NYC 9/11 Public Portal Document

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Fax: (212) 475-4122 **Phone:** (212) 477-8941

Project: NYC BOE H.S. For Leadership & Public Services
90 Trinity Place, New York, NY

Received: 2/19/02 5:50:00 PM
ATC Group #: 6749
Analysis Date: 2/22/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	*Volume*	*Area Analyzed*	*Non Asb*	*Asbestos Type(s)*	*# Structures 0.5μ-5*	*5μ*	*Analytical Sensitivity (S/cc)*	*Asbestos Concentration (S/mm²)*	*(S/cc)*	*Notes*
04 6749 -1	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
05 6749 -2	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
06 6749 -3	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
07 6749 -4	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
08 6749 -5	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
09 6749 -6	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
10 6749 -7	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
11 6749 -8	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

MARK PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

NYC 9/11 Public Portal Document

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Fax: (212) 475-4122 **Phone:** (212) 477-8941

Received: 2/19/02 5:50:00 PM
ATC Group #: 6749
Analysis Date: 2/22/02

Project: NYC BOE H.S. For Leadership & Public Services
90 Trinity Place, New York, NY

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	*Volume*	*Area Analyzed*	*Non Asb*	*Asbestos Type(s)*	*# Structures 0.5μ-5*	*5μ*	*Analytical Sensitivity (S/cc)*	*Asbestos Concentration (S/mm²)*	*(S/cc)*	*Notes*
12 6749 -9	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
13 6749 -10	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
14 6749 -11	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
15 6749 -12	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
16 6749 -13	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
17 6749 -14	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
18 6749 -15	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
19 6749 -16	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
20 6749 -17	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
21 6749 -18	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

MARK PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879