NYC 9/11 Public Portal Document

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Fax: (212) 475-4122 **Phone:** (212) 477-8941

Project: H.S. Of Economics And Finance

Received: 3/10/02 5:00:00 PM
ATC Group #: 7019
Analysis Date: 3/10/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5	# Structures 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
03 7019 -1	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
04 7019 -2	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
05 7019 -3	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
06 7019 -4	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
07 7019 -5	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
08 7019 -6	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
09 7019 -7	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
10 7019 -8	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

MARK PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

NYC-WTC_000384366

NYC 9/11 Public Portal Document

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101
Fax: (212) 475-4122 **Phone:** (212) 477-8941

Received: 3/10/02 5:00:00 PM
ATC Group #: 7019
Analysis Date: 3/10/02

Project: H.S. Of Economics And Finance

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5μ-5	# Structures 5μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
11 7019 -9	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
12 7019 -10	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
13 7019 -11	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
14 7019 -12	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
15 7019 -13	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
16 7019 -14	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
17 7019 -15	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
18 7019 -16	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
19 7019 -17	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

MARK PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

NYC-WTC_000384367