NYC 9/11 Public Portal Document

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: NYC-BOE PS 150M Project#: 14584-0824
334 Greenwich St., New York, NY. 10013

Received: 4.11.02 4:40:00 PM
ATC Group #: 7399
Analysis Date: 4.13.02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5μ-5	# Structures 5μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
01 7399 -1	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
02 7399 -2	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
03 7399 -3	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
04 7399 -4	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
05 7399 -5	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
06 7399 -6	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	

ROMAN PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_002919752

NYC-WTC_000397012