NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 1200

LOCATION PS150 M DATE 2/22/02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m^3)	TVOCs (ppm)
Outside South Side						8	
Outside SE Corner						9	
Bottom of Stairs Outside North Side						10	
Top of Stairs. Outside North Side						12	
Top of Stair Outside East						10	
Bottom of Stair Outside East						12	
Outside West						9	
Outside NE Corner						10	
Outside NW Corner						10	
Outside Main Entrance						11	
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m^3 24-hour average	1 ppm

Comments: Working in the Courtyard.

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: [signature] Date: 2/22/02

CITY_21MC100_000490368

NYC-WTC_000398024

NYC-WTC_000398025

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 1230

LOCATION PS150 M DATE 2/22/02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m^3)	TVOCs (ppm)
Main Foyer						10	
1st Fl. Hall by West Stair						9	
Main Desk						12	
Main Lobby Area						13	
Resource Rm						11	
Main Office						10	
Principal Office						9	
Ed's Room						8	
Hall by Boys Rm						10	
Hall by Girls RM						11	
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m^3 24-hour average	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: _____ Date: 2/22/02

CITY_21MC100_000490369

NYC-WTC_000398026

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 1300

LOCATION PS150 M DATE 2/22/02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m^3)	TVOCs (ppm)
1st Fl. Hall by East Stair						10	
Nurse Rm.						9	
Speech Rm.						8	
Kitchen						10	
Music Rm						8	
1st. Fl. East Stairs.						10	
404						6	
403						8	
402						10	
401						12	
Guideline levels ASHRAE/AIHA/EPA		**68 -75°F/winter 73 -79°F/summer**	**30-60%**	**Outdoor level + 700 ppm**	**9 ppm**	**65 ug/m^3 24-hour average**	**1 ppm**

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: Jay Chang Date: 2/22/02

CITY_21MC100_000490370

NYC-WTC_000398027

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 1330

LOCATION PS150 M DATE 2/22/02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m^3)	TVOCs (ppm)
401 (HALL)						12	
2nd FL Hall by Boys Rm						11	
2nd Fl. Hall by Girls Rm						10	
2nd. FL. Hall by Teacher Rm						12	
501						10	
502						8	
503						10	
504						12	
3rd FL. Hall by Slop Sink						10	
Hall by Rest Rms.						12	
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m^3 24-hour average	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: _____ Date: 2/22/02

CITY_21MC100_000490371