NYC 9/11 Public Portal Document

ATC Associates

10- East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Fax: (212) 475-4122 **Phone:** (212) 477-8941

Project: NYC-BOE PS 150M **Project#:** 14584-0824

Received: 4 4 [illegible] :00 PM
ATC Group #: 73[illegible]
Analysis Date: 4 4

Asbestos Fiber Analysis by Transmission Electron Microscope (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	*Volume*	*Area Analyzed*	*Non Asb*	*Asbestos Type(s)*	*# Structures 0.5μ-5*	*5μ*	*Analytical Sensitivity (S/cc)*	*Asbestos Concentration (S/mm²)*	*(S/cc,*
01 732	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
02 732	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
03 732	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
04 732	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
05 732	1912.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
06 732	1920.00	0.0450	0	None Detectec	0	0	0.0045	<22.24	<0.0045
07 732	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045

[illegible]RK PEYSAKHOV
Analyzed by:

[illegible]KI, Ph.D.
[illegible]By

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by [illegible]. [illegible] is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates. [illegible] may be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported [illegible] including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

[illegible]edited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_002894658

NYC-WTC_000398331