NYC 9/11 Public Portal Document

ATC ASSOCIATES INC.

104 East 25th St., 10th Floor
New York, New York 10010
www.atc-enviro.com
212.353.8280
Fax 212.353.8306

March 12, 2002

Mr. Bernard P. Orlan
Director, Environmental Health & Safety
New York City Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101-4008

Re: **Indoor Air Quality Assessment**
High School of Economics and Finance (M833)
100 Trinity Place
New York, New York 10006
ATC Project No. 15-19125-0291

Dear Mr. Orlan:

ATC Associates Inc. (ATC) is pleased to provide this report of indoor air quality (IAQ) measurements collected on March 11, 2002 at the referenced school. The New York City Board of Education (BOE) requested these measurements as part of a program to determine if acceptable indoor air quality is being maintained.

SCOPE OF WORK

ATC conducted this evaluation to assess the basic parameters of temperature, relative humidity, carbon dioxide (CO_2) and carbon monoxide (CO).

Total volatile organic compounds (TVOCs) and respirable particulates were also measured.

Prasad Doddapaneni, Environmental Technician, of ATC's New York City office, conducted the assessment. ATC's findings and conclusions are based on a visual inspection, real-time environmental measurements and conditions present in the school at the time of the assessment.

ATC measured temperature, relative humidity, CO_2 and CO with a Q-Trak® Model 8551, manufactured by TSI, Inc.

ATC measured concentrations of respirable particulates ($PM_{2.5}$) with a Dust-Trak® Aerosol Monitor Model 8520, manufactured by TSI, Inc.

ATC measured concentrations of TVOCs using a RAE Systems, Inc. MiniRAE® photoionization detector (PID).

The assessment was performed consistent with generally accepted indoor air quality assessment practices. As with all such assessments, there were inherent limitations created by constraints of time, operational and work practice variability, variations in indoor air quality parameters and sampling and analytical accuracy.

NYC-WTC_000402437

NYC 9/11 Public Portal Document

The results of the sampling represent conditions found on the dates of the survey and may not represent conditions found at other times. The information presented in this report should be used by the BOE as a guide to assess the need for further improvements in current indoor air quality control activities.

EVALUATION CRITERIA

Currently, there are no regulatory standards for indoor air quality in non-industrial buildings, such as offices and schools. For the real-time data collected, ATC uses the commonly accepted guidelines cited in the following publications:

- *Ventilation for Acceptable Indoor Air Quality (ASHRAE 62-1999)*, American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE);
- *Thermal Environmental Conditions for Human Occupancy (ASHRAE 55-1992);*
- *Industrial Hygienists Guide to Indoor Air Quality Investigations* (1993), American Industrial Hygiene Association (AIHA).

Table 1 lists target guidelines for the parameters that ATC evaluated during this investigation. Meeting one, some, or all of the listed values does not assure that acceptable indoor air quality will be achieved at all times.

TABLE 1
TARGET GUIDELINES FOR INDOOR AIR QUALITY PARAMETERS EVALUATED

PARAMETER	TARGET LEVEL	AGENCY OR ORGANIZATION
Carbon Dioxide (CO_2)	<700 parts per million (ppm) above background level	ASHRAE 62
Carbon Monoxide (CO)	9 ppm	ASHRAE 62 (adopted from USEPA NPAAQS)
Respirable Particulates ($PM_{2.5}$)	65 micrograms per cubic meter of air ($\mu g/m^3$) 24-hour average	USEPA NPAAQS
	40 $\mu g/m^3$ 24-hour average	USEPA – Recommendation for children / sensitive individuals
Temperature	Summer: 73-79°F at 50% RH Winter: 68-75°F at 50% RH	ASHRAE 55
Relative Humidity	30 – 60 %	ASHRAE 55
Total Volatile Organic Compounds (TVOC)	1 ppm	AIHA

USEPA = United States Environmental Protection Agency
NPAAQS = National Primary Ambient-Air Quality Standard
AIHA = American Industrial Hygiene Association

NYC-WTC_000402438

NYC 9/11 Public Portal Document

REAL-TIME ENVIRONMENTAL MEASUREMENTS

ATC collected one hundred (100) sets of real-time environmental measurements consisting of eighty-eight (88) in the school building and twelve (12) outdoors. Field data sheets are found in the Attachment. Readings began at 8:05 A.M. and concluded after14:58 P.M. The results are described below.

Temperature

Indoor dry bulb temperature measurements ranged from 56.1 °F to 70.6 °F. Twenty five (25) of the indoor measurements were below and sixty three (63) were within the range of 68 to 75°F (at 50 percent relative humidity) recommended by ASHRAE Standard 55-1992 during the heating season (wintertime conditions). The outdoor temperature ranged from 40.0 to47.0 °F.

Relative Humidity

The relative humidity indoors ranged from 16.8 percent to 37.3 percent. Eighty-four (84) measurements were below the ASHRAE-recommended range of 30 to 60 percent for occupant comfort. Four (4) measurements were within the ASHRAE recommended range. The outdoor relative humidity ranged from 15.8 to 22.3 percent.

Carbon Dioxide Concentration

Carbon dioxide concentrations indoors ranged from 64 ppm to 1321 ppm. All indoor measurements were below the ASHRAE Standard 62-1999 recommended maximum concentration of <700 ppm above the background level. The outdoor (background) CO_2 concentration was 746 ppm. Therefore, the maximum acceptable level of CO_2 at this location was 1446 ppm (background level + 700 ppm). The highest reading (1321 ppm) was measured in Room # 410 approximately at 9:03 AM. Please note that hallway was occupied by approximately 17 people. Levels above the recommended maximum do not indicate a health risk. Carbon dioxide measurements are used as an indicator of available outdoor air. The primary source of CO_2 indoors is occupant respiration.

Carbon Monoxide Concentration

Carbon monoxide concentrations indoors were between 1 to 2 ppm. These concentrations were below the NPAAQS/ASHRAE guideline of 9 ppm. The outdoor CO concentration ranged from 1 to 4 ppm.

Respirable Particulates ($PM_{2.5}$)

Respirable particulate concentrations* indoors ranged between 3 $\mu g/m^3$ to 71 $\mu g/m^3$ with an average 10 $\mu g/m^3$. Two (2) of the eighty-eight (88) instantaneous measurements were above the NPAAQS of 65 $\mu g/m^3$ 24-hour average concentration of particulate matter 2.5 micrometers or less in aerodynamic diameter. The indoor $PM_{2.5}$ average concentration was 10 $\mu g/m^3$ also below the USEPA recommended concentration of 40 $\mu g/m^3$ for sensitive individuals / children. The outdoor respirable particulate concentration ranged from 20 $\mu g/m^3$ to 112 $\mu g/m^3$ with an average of 55 $\mu g/m^3$. Three (3) of the outdoor measurements were above the NPAAQS of 65

NYC-WTC_000402439

NYC 9/11 Public Portal Document

$\mu g/m^3$ (24-hour average) and nine (9) outdoor measurements are above the USEPA recommended concentration of 40 $\mu g/m^3$ for sensitive individuals / children.

* The measurements made during this assessment were instantaneous readings, the NPAAQS is a 24-hour average.

TVOC Concentration

TVOCs were not detected anywhere inside the building (0.0 ppm). The outdoor TVOC concentration was also 0.0 ppm.

OBSERVATIONS

During this assessment, ATC noted the following:

- The interior of the building appeared clean and free of dust and debris;
- The building was occupied at the time of the assessment;
- No smoke odor was detected in the building;

FINDINGS

Based on the real-time measurements, the following findings are presented:

1. Concentrations of CO and TVOCs were below applicable standards and guidelines.
2. Eighty-four (84) measurements were below the ASHRAE-recommended range of 30 to 60 percent for occupant comfort. Four (4) measurements were within the ASHRAE recommended range.
3. Twenty five (25) of the indoor measurements were below and sixty three (63) were within the range of 68 to 75°F (at 50 percent relative humidity) recommended by ASHRAE Standard 55-1992 during the heating season (wintertime conditions).
4. Two (2) of the eighty-eight (88) instantaneous measurements were above the NPAAQS of 65 $\mu g/m^3$ 24-hour average concentration of particulate matter 2.5 micrometers or less in aerodynamic diameter. The indoor $PM_{2.5}$ average concentration was 10 $\mu g/m^3$ also below the USEPA recommended concentration of 40 $\mu g/m^3$ for sensitive individuals / children.

It is our pleasure to provide these indoor air quality services to the New York City Board of Education.

If you have any questions about this report, please call (212) 353-8280, extension 356 or 212.

Sincerely,
ATC ASSOCIATES INC.

Prasad Doddapaneni
Senior Project Manager

Reviewed by:

James R. Cohn, CIH, CSP
Regional Manager, Industrial Hygiene Division

Attachment

NYC-WTC_000402440