EMSL Analytical, Inc.
307 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2122900058 Email:

Attn:	CTSI-Consulting & Testing Services, Inc. 622 George Rd. North Brunswick, NJ 08902	Customer ID:	CTSI50
		Customer PO:	
Fax:	(732) 729-1803 Phone: 732-729-1800	Received:	03/12/02 7:10 PM
Project:	**NY-100-02 / NYU / 200 WATER STREET**	EMSL Order:	030203225
		EMSL Project ID:	
		Analysis Date:	3/13/2002

Fiber Analysis of Air Samples via NIOSH 7400, Revision 3, Issue 2, 8/15/94

Sample	*Location*	*Sample Date*	*Volume*	*Fibers*	*Fields*	*LOD (fib/cc)*	*Fibers/ mm²*	*Fibers/ cc*	*Notes*
001 *030203225-0001*	5TH FLOOR, HALLWAY, ELV. LOBBY	3/12/2002	1350.00	<5.5	100	0.002	<7.0	<0.002	
002 *030203225-0002*	5TH FLOOR, ROOM 502	3/12/2002	1350.00	<5.5	100	0.002	<7.0	<0.002	
003 *030203225-0003*	5TH FLOOR, ROOM 510	3/12/2002	1350.00	<5.5	100	0.002	<7.0	<0.002	
004 *030203225-0004*	5TH FLOOR, ROOM 514	3/12/2002	1350.00	<5.5	100	0.002	<7.0	<0.002	
005 *030203225-0005*	5TH FLOOR, ROOM 518	3/12/2002	1350.00	<5.5	100	0.002	<7.0	<0.002	
006 *030203225-0006*	3RD FLOOR, HALLWAY, ELV. LOBBY	3/12/2002	1350.00	<5.5	100	0.002	<7.0	<0.002	
007 *030203225-0007*	3RD FLOOR, ROOM 302	3/12/2002	1350.00	<5.5	100	0.002	<7.0	<0.002	
008 *030203225-0008*	3RD FLOOR, ROOM 310	3/12/2002	1350.00	<5.5	100	0.002	<7.0	<0.002	
009 *030203225-0009*	3RD FLOOR, ROOM 314	3/12/2002	1350.00	<5.5	100	0.002	<7.0	<0.002	
010 *030203225-0010*	3RD FLOOR, ROOM 318	3/12/2002	1350.00	<5.5	100	0.002	<7.0	<0.002	
011 *030203225-0011*	2ND FLOOR, HALLWAY, ELV. LOBBY	3/12/2002	1350.00	<5.5	100	0.002	<7.0	<0.002	
012 *030203225-0012*	2ND FLOOR, ROOM 202	3/12/2002	1350.00	<5.5	100	0.002	<7.0	<0.002	

Dawnette Branson
Analyst

Laboratory Manager
or other approved signatory

Limit of detection is 7 fibers/mm². The laboratory is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.
Analysis performed by EMSL Manhattan (NY State ELAP #11506)

PCM-1

CONFIDENTIAL, SUBJECT TO PROTECTIVE ORDER NO. 1, JAN. 2013

EMSL Analytical, Inc.
307 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2122900058 Email:

Attn: CTSI-Consulting & Testing Services, Inc.
622 George Rd.
North Brunswick, NJ 08902
Fax: (732) 729-1803 Phone: 732-729-1800
Project: **NY-100-02 / NYU / 200 WATER STREET**

Customer ID: CTSI50
Customer PO:
Received: 03/12/02 7:10 PM
EMSL Order: 030203225
EMSL Project ID:
Analysis Date: 3/13/2002

Fiber Analysis of Air Samples via NIOSH 7400, Revision 3, Issue 2, 8/15/94

Sample	*Location*	*Sample Date*	*Volume*	*Fibers*	*Fields*	*LOD (fib/cc)*	*Fibers/ mm²*	*Fibers/ cc*	*Notes*
013 *030203225-0013*	2ND FLOOR, ROOM 210	3/12/2002	1350.00	<5.5	100	0.002	<7.0	<0.002	
014 *030203225-0014*	2ND FLOOR, ROOM 214	3/12/2002	1350.00	<5.5	100	0.002	<7.0	<0.002	
015 *030203225-0015*	2ND FLOOR, ROOM 218	3/12/2002	1350.00	<5.5	100	0.002	<7.0	<0.002	
016 *030203225-0016*	19TH FLOOR, HALLWAY	3/12/2002	1800.00	<5.5	100	0.001	<7.0	<0.001	
017 *030203225-0017*	19TH FLOOR, ROOM 1910	3/12/2002	1800.00	<5.5	100	0.001	<7.0	<0.001	
018 *030203225-0018*	19TH FLOOR, ROOM 1902	3/12/2002	1800.00	<5.5	100	0.001	<7.0	<0.001	
019 *030203225-0019*	19TH FL ROOM 1918	3/12/2002	1800.00	<5.5	100	0.001	<7.0	<0.001	
020 *030203225-0020*	19TH FL ROOM 1914	3/12/2002	1800.00	<5.5	100	0.001	<7.0	<0.001	
021 *030203225-0021*	18TH FL HALLWAY	3/12/2002	1800.00	<5.5	100	0.001	<7.0	<0.001	
022 *030203225-0022*	18TH FL ROOM 1818	3/12/2002	1800.00	<5.5	100	0.001	<7.0	<0.001	
023 *030203225-0023*	18TH FL ROOM 1814	3/12/2002	1800.00	<5.5	100	0.001	<7.0	<0.001	
024 *030203225-0024*	18TH FL ROOM 1810	3/12/2002	1800.00	<5.5	100	0.001	<7.0	<0.001	

Dawnette Branson
Analyst

Laboratory Manager
or other approved signatory

Limit of detection is 7 fibers/mm². The laboratory is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.
Analysis performed by EMSL Manhattan (NY State ELAP #11506)

CM-

CONFIDENTIAL, SUBJECT TO PROTECTIVE ORDER NO. 1, JAN. 2013

EMSL Analytical, Inc.
307 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2122900058 Email:

Attn: CTSI-Consulting & Testing Services, Inc.
622 George Rd.
North Brunswick, NJ 08902
Fax: (732) 729-1803 Phone: 732-729-1800
Project: **NY-100-02 / NYU / 200 WATER STREET**

Customer ID: CTSI50
Customer PO:
Received: 03/12/02 7:10 PM
EMSL Order: 030203225
EMSL Project ID:
Analysis Date: 3/13/2002


Fiber Analysis of Air Samples via NIOSH 7400, Revision 3, Issue 2, 8/15/94

Sample	*Location*	*Sample Date*	*Volume*	*Fibers*	*Fields*	*LOD (fib/cc)*	*Fibers/ mm²*	*Fibers/ cc*	*Notes*
025 *030203225-0025*	18TH FL ROOM 1802	3/12/2002	1800.00	<5.5	100	0.001	<7.0	<0.001	
026 *030203225-0026*	21ST FLOOR, HALLWAY	3/12/2002	1380.00	<5.5	100	0.002	<7.0	<0.002	
027 *030203225-0027*	21ST FLOOR, ROOM 2118	3/12/2002	1425.00	<5.5	100	0.002	<7.0	<0.002	
028 *030203225-0028*	21ST FLOOR, ROOM 2114	3/12/2002	1455.00	<5.5	100	0.002	<7.0	<0.002	
029 *030203225-0029*	21ST FLOOR, ROOM 2102	3/12/2002	1440.00	<5.5	100	0.002	<7.0	<0.002	
030 *030203225-0030*	21ST FLOOR, ROOM 2110	3/12/2002	1440.00	<5.5	100	0.002	<7.0	<0.002	
031 *030203225-0031*	30TH FLOOR, ROOM 3018	3/12/2002	1800.00	<5.5	100	0.001	<7.0	<0.001	
032 *030203225-0032*	30TH FLOOR, HALLWAY	3/12/2002	1800.00	<5.5	100	0.001	<7.0	<0.001	
033 *030203225-0033*	30TH FLOOR ROOM 3014	3/12/2002	1800.00	<5.5	100	0.001	<7.0	<0.001	
034 *030203225-0034*	30TH FLOOR, ROOM 3010	3/12/2002	1800.00	<5.5	100	0.001	<7.0	<0.001	
035 *030203225-0035*	30TH FLOOR, ROOM 3002	3/12/2002	1800.00	<5.5	100	0.001	<7.0	<0.001	
036 *030203225-0036*	26TH FLOOR, HALLWAY	3/12/2002	1830.00	<5.5	100	0.001	<7.0	<0.001	

Dawnette Branson
Analyst

Laboratory Manager
or other approved signatory

Limit of detection is 7 fibers/mm². The laboratory is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.
Analysis performed by EMSL Manhattan (NY State ELAP #11506)



CONFIDENTIAL, SUBJECT TO PROTECTIVE ORDER NO. 1, JAN. 2013

EMSL Analytical, Inc.
307 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2122900058 Email:

Attn: CTSI-Consulting & Testing Services, Inc.
622 George Rd.
North Brunswick, NJ 08902
Fax: (732) 729-1803 Phone: 732-729-1800
Project: **NY-100-02 / NYU / 200 WATER STREET**

Customer ID: CTSI50
Customer PO:
Received: 03/12/02 7:10 PM
EMSL Order: 030203225
EMSL Project ID:
Analysis Date: 3/13/2002

Fiber Analysis of Air Samples via NIOSH 7400, Revision 3, Issue 2, 8/15/94

Sample	*Location*	*Sample Date*	*Volume*	*Fibers*	*Fields*	*LOD (fib/cc)*	*Fibers/ mm²*	*Fibers/ cc*	*Notes*
037 *030203225-0037*	26TH FLOOR, ROOM 2618	3/12/2002	1830.00	<5.5	100	0.001	<7.0	<0.001	
038 *030203225-0038*	26TH FLOOR, ROOM 2614	3/12/2002	1815.00	<5.5	100	0.001	<7.0	<0.001	
039 *030203225-0039*	26TH FLOOR, ROOM 2610	3/12/2002	1860.00	<5.5	100	0.001	<7.0	<0.001	
040 *030203225-0040*	26TH FLOOR, ROOM 2602	3/12/2002	1860.00	<5.5	100	0.001	<7.0	<0.001	
041 *030203225-0041*	25TH FLOOR, HALLWAY	3/12/2002	1770.00	<5.5	100	0.002	<7.0	<0.002	
042 *030203225-0042*	25TH FLOOR, ROOM 2518	3/12/2002	1740.00	<5.5	100	0.002	<7.0	<0.002	
043 *030203225-0043*	25TH FLOOR, ROOM 2514	3/12/2002	1715.00	<5.5	100	0.002	<7.0	<0.002	
044 *030203225-0044*	25TH FLOOR, ROOM 2510	3/12/2002	1740.00	<5.5	100	0.002	<7.0	<0.002	
045 *030203225-0045*	25TH FLOOR, ROOM 2502	3/12/2002	1740.00	<5.5	100	0.002	<7.0	<0.002	

Dawnette Branson
Analyst

Laboratory Manager
or other approved signatory

Limit of detection is 7 fibers/mm². The laboratory is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.
Analysis performed by EMSL Manhattan (NY State ELAP #11506)

CM

CONFIDENTIAL, SUBJECT TO PROTECTIVE ORDER NO. 1, JAN. 2013