NYC 9/11 Public Portal Document

Newmark Real Estate
17 Battery Place
Data Summary

Date	Sample ID	Area Tested	Matrix (Air/Bulk)	Analytical Method	Results (Pos./Neg.)	Asbestos Type
10/3/01	01D	13th floor-Lobby	Air	TEM		OVERLOAD
10/3/01	02D	12th floor-Hallway	Air	TEM	<16.00	None Detected
10/3/01	03D	10th floor-Hallway	Air	TEM	32	Chrysotile
10/3/01	04D	9th floor-Hallway	Air	TEM	<16.00	None Detected
10/3/01	05D	8th floor-Middle East Rm	Air	TEM	<16.00	None Detected
10/3/01	06D	7th floor-Hallway	Air	TEM	<16.00	None Detected
10/3/01	07D	6th floor-Hallway	Air	TEM	<16.00	None Detected
10/3/01	08D	5th floor-Miudle East Rm	Air	TEM	<16.00	None Detected
10/3/01	09D	4th floor-South East Office	Air	TEM	<16.00	None Detected
10/3/01	10D	3rd floor-Hallway	Air	TEM	13.33	Chrysotile
10/3/01	11D	2nd floor-Hallway	Air	TEM	<13.33	None Detected
10/3/01	12D	1st floor-Lobby	Air	TEM	<13.33	None Detected
10/3/01	13D	QA/QC blank	Air	TEM	N/A	None Detected
10/3/01	14D	QA/QC blank	Air	TEM	N/A	None Detected

CONFIDENTIAL, CITY_21MC100_003387157

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000409059