NYC 9/11 Public Portal Document

Newmark Real Estate
17 Battery Place
Data Summary

Date	Sample ID	Area Tested	Matrix (Air/Bulk)	Analytical Method	Results (Pos./Neg.)	Asbestos Type
11/1/01	1	13th floor	Air	TEM	<19.38	None Detected
11/1/01	2	12th floor	Air	TEM	<19.38	None Detected
11/1/01	3	11th floor	Air	TEM	<19.38	None Detected
11/1/01	4	10th floor	Air	TEM	<19.38	None Detected
11/1/01	5	9th floor	Air	TEM	<19.38	None Detected
11/1/01	6	8th floor	Air	TEM	<19.38	None Detected
11/1/01	7	7th floor	Air	TEM	<19.38	None Detected
11/1/01	8	6th floor	Air	TEM	<19.38	None Detected
11/1/01	9	5th floor	Air	TEM	<19.38	None Detected
11/1/01	10	4th floor	Air	TEM	<19.38	None Detected
11/1/01	11	3rd floor	Air	TEM	<19.38	None Detected
11/1/01	12	2nd floor	Air	TEM	<19.38	None Detected
11/1/01	13	1st floor	Air	TEM	<19.38	None Detected
11/1/01	14	lobby	Air	TEM	<19.38	None Detected
11/1/01	15	basement AC room adj to door	Air	TEM	<19.38	None Detected
11/1/01	16	basement AC room mid	Air	TEM	<19.38	None Detected
11/1/01	17	lower basement mid	Air	TEM	<19.38	None Detected
11/1/01	18	hallway adj to AC room	Air	TEM	<19.38	None Detected
11/1/01	19	QA/QC blank	Air	TEM	N/A	None Detected
11/1/01	20	QA/QC blank	Air	TEM	N/A	None Detected

CONFIDENTIAL, CITY_21MC100_003387161

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000409063