NYC 9/11 Public Portal Document

ATC ASSOCIATES INC.

BATCH NO. 19943

BULK SAMPLE DATA AND CHAIN OF CUSTODY FORM

PROJECT INFORMATION

1. Client: NYC - BOE	2. Project Nam AHERA REINSPECTION	3. Project # 14584-0823	4. Project Manager: ANDREAS ANDREOU
	2a. Project Address: 292 Greenwich street, New York, NY 10007		4a. Investigator: Yiannis Efstathiou

5. Date:	6. Building Name: PS 234M	8. Turnaround Time:	9. Comments (Field):
1/22/02	7. Sampling Areas:	☐ STAT ☐ 24 HRS ☐ 72 HRS ☐ OTHER ☐ 6 HRS ☐ 48 HOURS ☐ NORMAL	Analyzed all them for fiberglass 10. Time in / Time out:

H.A.#	SAMPLE ID NUMBER	MATERIAL DESCRIPTION	LOCATION	FLOOR NUMBER	RESULTS
	PS234M-1/22/02-01 Fiberglass-	Settled Dust	1st Floor hallway by Cafeteria		27% Fiberglass
	PS234M-1/22/02-02 Fiberglass-	Settled Dust	Cafeteria		8% Fiberglass
	PS234M-1/22/02-03 Fiberglass-	Settled Dust	Gymnasium		17% Fiberglass
	PS234M-1/22/02-04 Fiberglass-	Settled Dust	Auditorium		9% Fiberglass
	PS234M-1/22/02-05 Fiberglass-	Settled Dust	Classroom #202 (Facing east)		3% Fiberglass
	PS234M-1/22/02-06	Settled Dust	Classroom #211 (Facing south)		1% Fiberglass
	PS234M-1/22/02-07	Settled Dust	Classroom #305 (Facing south)		2% Fiberglass

CHAIN OF CUSTODY

17. Relinquished By:	18. Date:	19. Time:	20. Received By:	21. Date:	22. Time:
Yiannis Efstathiou	1/22/02		[illegible]	01/22/02	1600

23. Method of Submittal:	
FIELD	
WALK IN	
US MAIL	
FED-X	
OTHER	

LAB INFORMATION

24. Name and Signature:	25. Date:	26. Time:
24a. Analyzed By: E. A. CHARTEROS	1/22/02	PM
24b. Analyzed By:		
24c. QC By:		

27. Comments (Lab): 7 PLM

Filename: P:\USERS\DATA\WP96\WP\FORMS\NY-13.XLS

Form NY-13

CONFIDENTIAL, CITY_21MC100_003388354

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000410317