NYC 9/11 Public Portal Document

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Fax: (212) 475-4122 **Phone:** (212) 477-8941

Project: New Stuyvesant H. S. , 345 Chambers St., NY , N
Exterior and Interior of Building and Roof

Received: 3/18/02 8:00:00 PM
ATC Group #: 7122
Analysis Date: 3/18/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5μ-5	# Structures 5μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
1 7122 -1	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
2 7122 -2	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
3 7122 -3	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
4 7122 -4	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
5 7122 -5	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
6 7122 -6	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
7 7122 -7	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	

ROMAN PEYSAKHOV
Analyzed by: RPey

MICHAEL A. GORYCKI, Ph.D.
Approved by: Michael A Goryck

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CONFIDENTIAL, CITY_21MC100_003388529

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000410645

NYC 9/11 Public Portal Document

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101
Fax: (212) 475-4122 **Phone:** (212) 477-8941

Received: 3/18/02 8:00:00 PM
ATC Group #: 7122
Analysis Date: 3/18/02

Project: New Stuyvesant H. S. , 345 Chambers St., NY , N
Exterior and Interior of Building and Roof

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5	# Structures 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
8 7122 -8	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
9 7122 -9	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
10 7122 -10	1952.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
11 7122 -11	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
12 7122 -12	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
13 7122 -13	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
14 7122 -14	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
15 7122 -15	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
16 7122 -16	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	

ROMAN PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CONFIDENTIAL, CITY_21MC100_003388530

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000410646

NYC 9/11 Public Portal Document

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101
Fax: (212) 475-4122 **Phone:** (212) 477-8941

Received: 3/18/02 8:00:00 PM
ATC Group #: 7122
Analysis Date: 3/18/02

Project: New Stuyvesant H. S. , 345 Chambers St., NY , N
Exterior and Interior of Building and Roof

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5μ-5	# Structures 5μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
17 7122 -17	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
18 7122 -18	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
19 7122 -19	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
20 7122 -20	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
21 7122 -21	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	

ROMAN PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CONFIDENTIAL, CITY_21MC100_003388531

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC-WTC_000410647