NYC 9/11 Public Portal Document

ATHENICA
ENVIRONMENTAL SERVICES INC.
Tel: (718) 784-7490
Fax: (718) 784-4085

CLIENT: SCA
SITE: Economics HS 111 100 Tenth Pl
PROJECT NO. (ATHENICA FILE#): 01-0613
DATE: 11/30/01
PURPOSE OF MONITORING: AREA SAMPLING
TECHNICIAN: G Lopez
CASETTE SIZE: 25 mm
LOT#:
ROTOMETER#: GL-1001
BATCH#: 01-11-091
TYPE-OF-RESPIRATOR:
PROJECT MANAGER: V. Bellas
AREAS OF ABATEMENT: Basement
TYPE-OF-REMOVAL: Dust Control

PCM [✓] TEM [ ]
CHECK ONLY ONE BOX

Background [ ] Pre-Abatement [ ] Durrings [ ] Finals [ ] Others (Explain) Ambient
(CHECK ONLY ONE BOX)

SAMPLE ID#	LOCATION	TYPE *	PUMP	TIME IN	TIME OUT	TOTAL MIN.	FLOW BEFORE	FLOW AFTER	FLOW AVERAGE	VOLUME	FIBERS/ FIELD	FIBERS/ C.C.
1	At Basement Level by Staircase "D"	Final		0835	1005	90	14	14	14	1260	04/1mm	<.01
2	Center of Gym			0836	1006	90	14	VOID		NO Power	NS Per Bldg	
3	Storage Adjacent to Gym			0839	1008	90	14	14	14	1260	05/1mm	<.01
4	Locker Room Boys			0840	1010	90	14	VOID		NO Power		—
5	Locker Room Girls			0841	1011	90	14	14	14	1260	05/1mm	<.01
6	Electric Switch Board Rm Center			0843	1013	90	14	14	14	1260	04/1mm	
7	Hallway by Staircase "B"			0845	1015	90	14	14	14	1260	02/1mm	
8	By old Elevator Shaft			0847	1017	90	14	14	14	1260	05/1mm	
9	By Custodian Large Center			0848	1018	90	14	14	14	1260	03/1mm	
10	Hallway by Rm B11			0850	1020	90	14	14	14	1260	04/1mm	
11	Fan Rm by Work Bench	✓		0852	1022	90	14	14	14	1260	08/1mm	

BGA - Backround
PRE - Preabatement
IWA - Inside Work Area
OB - Outside Building
ICR - Inside Clean Room
NGAE - Negative Air Exhaust
OWA - Outside work area
OTH - Other
OFNL Outside Finals
IFNL - Inside Finals

CHAIN OF CUSTODY RECORD

RELINQUISHED BY :	G Lopez	DATE :	11/30/01	TIME :	1400
RECEIVED BY :		DATE :	11.30.01	TIME :	13:00
ANALYST :		DATE :	11.30.01	TIME :	13:45

LABORATORY ACCREDITATION :
NVLAP# 101958 ELAP# 10955 METHOD : NIOSH 7400

WHITE-FILE/LAB YELLOW-CLIENT/REPORT PINK-FIELD

01/23/2002 14:09 FAX 718 784 4085 CITY_21MC100_002940600
2011

NYC 9/11 Public Portal Document

ATHENICA
ENVIRONMENTAL SERVICES INC.
Tel: (718) 784-7490
Fax: (718) 784-4085

CLIENT: SCA
SITE: Economics HS.. M. 100 Trinity
PROJECT NO. (ATHENICA FILE#): 01-0613
DATE: 11/30/01
PURPOSE OF MONITORING: AREA SAMPLING
TECHNICIAN: G Lopez
CASETTE SIZE: 25 mm
LOT#:
ROTOMETER#: GL-04
BATCH#: 01-11-091
TYPE-OF-RESPIRATOR:
PROJECT MANAGER: V. Bellad
AREAS OF ABATEMENT: 7th and 11th Fl
TYPE-OF-REMOVAL: Dust Control

PCM [✓] TEM [ ]
CHECK ONLY ONE BOX

Background [ ] Pre-Abatement [ ] Durrings [ ] Finals [ ] Others (Explain) Ambient
(CHECK ONLY ONE BOX)

SAMPLE ID#	LOCATION	TYPE *	PUMP	TIME IN	TIME OUT	TOTAL MIN.	FLOW BEFORE	FLOW AFTER	FLOW AVERAGE	VOLUME	FIBERS/ FIELD	FIBERS/ C.C.
12	7th Fl In Fan Room by Rm 707	First		0940	1040	90	14	14	14	1260	15/fld	<.01
13	7th Fl. In Storage 707			0908	1038	90	14	14	14	1260	02/fld	
14	10th Fl In Absorber Tank Room North			0928	1058	90	14	14	14	1260	06/fld	
15	11th Fl In B Elevator Mech Rm Core			0930	1100	90	14	14	14	1260	10/fld	
16	11th Fl In Absorber Tank Rm South			0931	1101	90	14	14	14	1260	04/fld	
17	11th Fl Abv Ceiling E Elevator Mech Rm	↓		0933	1103	90	14	14	14	1260	11/fld	
18	F/B										00/fld	—
19	F/B										00/fld	—

BGA - Backround
PRE - Preabatement
IWA - Inside Work Area
OB - Outside Building
ICR - Inside Clean Room
NGAE - Negative Air Exhaust
OWA - Outside work area
OTH - Other
OFNL Outside Finals
IFNL - Inside Finals

CHAIN OF CUSTODY RECORD

RELINQUISHED BY :		DATE :	11/30/01	TIME :	13:00
RECEIVED BY :		DATE :	11.30.01	TIME :	13:00
ANALYST :		DATE :	11.30.01	TIME :	13:45

LABORATORY ACCREDITATION :
NVLAP# 101958 ELAP# 10955 METHOD : NIOSH 7400

WHITE-FILE/LAB YELLOW-CLIENT/REPORT PINK-FIELD

012

01/23/2002 14:09 FAX 718 784 4085 CITY_21MC100_002940601

NYC-WTC_000418568