NYC 9/11 Public Portal Document

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 *Fax: (516) 997-7528*

Attn.:
Taylor Environmental Group, Inc.
Floral Park Corporate Center
130-A Jericho Tpke.
Floral Park, NY 11001

Friday, February 22, 2002

Ref Number: LI023032

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: SCA 100 TRINITY PL.

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES > 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
F-01	1805.00	None Detected			0	0.0508	0.0042	<19.69	<0.0042
F-02	1805.00	None Detected			0	0.0508	0.0042	<19.69	<0.0042
F-03	1805.00	None Detected			0	0.0508	0.0042	<19.69	<0.0042
F-04	1853.00	None Detected			0	0.0508	0.0041	<19.69	<0.0041
F-05	1805.00	None Detected			0	0.0508	0.0042	<19.69	<0.0042
F-06	1853.00	None Detected			0	0.0508	0.0041	<19.69	<0.0041

Earl Tracey
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

1

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11408, CA ELAP 2329, CT PH-0349

CITY_21MC100_010190633

NYC-WTC_000418908

NYC 9/11 Public Portal Document

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Taylor Environmental Group, Inc.
Floral Park Corporate Center
130-A Jericho Tpke.
Floral Park, NY 11001

Friday, February 22, 2002

Ref Number: LI023032

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: SCA 100 TRINITY PL.

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES > 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
F-07	1805.00	None Detected			0	0.0508	0.0042	<19.69	<0.0042
F-08	1900.00	None Detected			0	0.0508	0.0040	<19.69	<0.0040
F-09	1900.00	None Detected			0	0.0508	0.0040	<19.69	<0.0040
F-10	1853.00	None Detected			0	0.0508	0.0041	<19.69	<0.0041
F-11	1805.00	None Detected			0	0.0508	0.0042	<19.69	<0.0042
F-12	1805.00	None Detected			0	0.0508	0.0042	<19.69	<0.0042

Earl Tracey
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11459, CA ELAP 2930, CT PH-0210

NYC-WTC_000418909

NYC 9/11 Public Portal Document

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Taylor Environmental Group, Inc.
Floral Park Corporate Center
130-A Jericho Tpke.
Floral Park, NY 11001

Friday, February 22, 2002

Ref Number: LI023032

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: SCA 100 TRINITY PL.

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES > 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm^2)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm^2)	Asbestos Concentration (S/cc)
F-13	1900.00	None Detected			0	0.0508	0.0040	<19.69	<0.0040
F-14	1805.00	None Detected			0	0.0508	0.0042	<19.69	<0.0042
F-15	1805.00	None Detected			0	0.0508	0.0042	<19.69	<0.0042
F-16	1853.00	None Detected			0	0.0508	0.0041	<19.69	<0.0041
F-17	1900.00	None Detected			0	0.0508	0.0040	<19.69	<0.0040
F-18	1805.00	None Detected			0	0.0508	0.0042	<19.69	<0.0042

Earl Tracey
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm^2. This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

3

CITY_21MC100_010190635

NYC-WTC_000418910

NYC 9/11 Public Portal Document

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Taylor Environmental Group, Inc.
Floral Park Corporate Center
130-A Jericho Tpke.
Floral Park, NY 11001

Friday, February 22, 2002

Ref Number: LI023032

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: SCA 100 TRINITY PL.

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES > 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
F-19	1805.00	None Detected			0	0.0508	0.0042	<19.69	<0.0042
F-20	1805.00	None Detected			0	0.0508	0.0042	<19.69	<0.0042
F-21	1853.00	None Detected			0	0.0508	0.0041	<19.69	<0.0041
F-22	1824.00	None Detected			0	0.0508	0.0042	<19.69	<0.0042
F-23	1824.00	None Detected			0	0.0508	0.0042	<19.69	<0.0042
F-24	1814.50	None Detected			0	0.0508	0.0042	<19.69	<0.0042

Earl Tracey
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

4

Applied for NVLAP, NJ PLM/TEM #101048-10, NY ELAP 11450, CA ELAP 2329, CT PH-0240

CITY_21MC100_010190636

NYC-WTC_000418911

NYC 9/11 Public Portal Document

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Taylor Environmental Group, Inc.
Floral Park Corporate Center
130-A Jericho Tpke.
Floral Park, NY 11001

Friday, February 22, 2002

Ref Number: LI023032

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: SCA 100 TRINITY PL.

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES > 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
F-25	1824.00	None Detected			0	0.0508	0.0042	<19.69	<0.0042
F-26	1824.00	None Detected			0	0.0508	0.0042	<19.69	<0.0042
F-27	1824.00	None Detected			0	0.0508	0.0042	<19.69	<0.0042
F-28	1833.50	None Detected			0	0.0508	0.0041	<19.69	<0.0041
F-29	1843.00	None Detected			0	0.0508	0.0041	<19.69	<0.0041
F-30	1940.00	None Detected			0	0.0508	0.0039	<19.69	<0.0039

Earl Tracey
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

5

Accredited for NVLAP PLM/TEM #101048-10, NY ELAP 11459, CA ELAP 2239, CT PH-0249

NYC 9/11 Public Portal Document

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Taylor Environmental Group, Inc.
Floral Park Corporate Center
130-A Jericho Tpke.
Floral Park, NY 11001

Friday, February 22. 2002

Ref Number: LI023032

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: SCA 100 TRINITY PL.

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES > 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
F-31	1843.00	None Detected			0	0.0508	0.0041	<19.69	<0.0041
F-32	1843.00	None Detected			0	0.0508	0.0041	<19.69	<0.0041
F-33	1843.00	None Detected			0	0.0508	0.0041	<19.69	<0.0041
F-34	1843.00	None Detected			0	0.0508	0.0041	<19.69	<0.0041
F-35	1881.75	None Detected			13	0.0508	0.0040	<19.69	<0.0040
F-36	1940.00	None Detected			1	0.0508	0.0039	<19.69	<0.0039

Michelle McGowan
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. *This report relates only to the samples reported above.* Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP, PLM/TEM #101048-10, NY-ELAP 11480, CA-ELAP 2350, CT PH-0040

CITY_21MC100_010190638

NYC-WTC_000418913

NYC 9/11 Public Portal Document

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Taylor Environmental Group, Inc.
Floral Park Corporate Center
130-A Jericho Tpke.
Floral Park, NY 11001

Friday, February 22, 2002

Ref Number: LI023032

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: SCA 100 TRINITY PL.

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES > 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm^2)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm^2)	Asbestos Concentration (S/cc)
F-37	1833.50	None Detected			1	0.0508	0.0041	<19.69	<0.0041
F-38	1833.50	None Detected			6	0.0508	0.0041	<19.69	<0.0041
F-39	1940.00	None Detected			0	0.0508	0.0039	<19.69	<0.0039
F-40	1940.00	None Detected			1	0.0508	0.0039	<19.69	<0.0039
F-41	1881.75	None Detected			0	0.0508	0.0040	<19.69	<0.0040
F-42	1843.00	None Detected			0	0.0508	0.0041	<19.69	<0.0041

Michelle McGowan
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm^2. This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-12, NY ELAP 11468, CA ELAP 2339, CT PH-0249

CITY_21MC100_010190639

NYC-WTC_000418914

NYC 9/11 Public Portal Document

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Taylor Environmental Group, Inc.
Floral Park Corporate Center
130-A Jericho Tpke.
Floral Park, NY 11001

Friday, February 22, 2002

Ref Number: LI023032

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: SCA 100 TRINITY PL.

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES > 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
F-43	1901.25	None Detected			0	0.0508	0.0040	<19.69	<0.0040
F-44	1950.00	None Detected			0	0.0508	0.0039	<19.69	<0.0039
F-45	1901.25	None Detected			0	0.0508	0.0040	<19.69	<0.0040
F-46	1852.50	None Detected			0	0.0508	0.0041	<19.69	<0.0041
F-47	1891.50	None Detected			4	0.0508	0.0040	<19.69	<0.0040
F-48	1843.00	None Detected			0	0.0508	0.0041	<19.69	<0.0041

Michelle McGowan
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

8

Accredited for NVLAP PLM/TEM #101048-10, NY-ELAP 11480, CA-ELAP 2239, CT-PH-0240

NYC-WTC_000418915

NYC 9/11 Public Portal Document

EMSL Analytical, Inc.

208 Stonehinge Lane
Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528

Attn.:
Taylor Environmental Group, Inc.
Floral Park Corporate Center
130-A Jericho Tpke.
Floral Park, NY 11001

Friday, February 22, 2002

Ref Number: LI023032

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Project: SCA 100 TRINITY PL.

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES > 0.5µ - < 5µ	# STRUCTURES ≥ 5µ	# STRUCTURES Non-Asbestos	Area Analyzed (mm²)	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)
F-49	1843.00	None Detected			0	0.0508	0.0041	<19.69	<0.0041
F-50	1833.50	None Detected			0	0.0508	0.0041	<19.69	<0.0041

Michelle McGowan
Analyst

Approved Signatory

Disclaimers: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This laboratory is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-10, NY-FLAP-11459, CA-FLAP-2339, CT-PH-0249

CITY_21MC100_010190641

NYC-WTC_000418916