NYC 9/11 Public Portal Document

ATC ASSOCIATES INC.
104 East 25th Street
New York, New York 10010
www.atc-enviro.com
212.353.8280
Fax 212.353.8306

October 15, 2001

Warren & Panzer Engineers, P.C.
228 E. 45th Street
New York, NY 10017
Attn: Mr. Fabio Pedone

Re: Report of TEM Analysis

Dear Mr. Pedone:

Following are the results of transmission electron microscopy (TEM) analysis of 4 wipe samples from our Group No. 5692:

Client: NYCSCA
Project Name: P.S. 234M
W&P File Numbers: 1030.53.01
WKP LOG I.D. Numbers: B011023-01 to 04
ATC Sample Numbers: 61266-61269
Samples received in TEM Lab.: 10/15/01

These results will confirm and document the data transmitted today to your office. Each sample was sonicated to produce 100 ml of a suspension of released particulates and possible asbestos structures. Each suspension in its entirety was passed through a 0.1 um polycarbonate filter, carbon coated, the filter dissolved, and analyzed. Only traces of chrysotile asbestos structures were detected in each filter.

The analyses were supervised by Dr. Michael A. Gorycki, Director of Electron Microscopy. We are pleased to note that our TEM lab has received full accreditation from NVLAP and also approval under the NY State DOH ELAP program, as is currently required for recognized analysis of TEM air samples for AHERA projects. These analyses were performed by ATC d/b/a ATC Associates Inc. This report may be reproduced only in its entirety and not without prior permission of this laboratory. Please contact me regarding any questions relating to these materials.

Very truly yours,

Michael A. Gorycki, Ph.D.
Director of Electron Microscopy

NYC-WTC_000420364