NYC 9/11 Public Portal Document

New York Lab
207 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2122900052 Email:

Attn: Larry Zaccherio
Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001
Fax (516) 358-1780 Phone: 516-358-2955
Project: PS 234M / Basement Through 3rd Floor

Customer ID: TAYL50
Customer PO:
Received: 10/16/01 8:30 PM

EMSL Order: 030106348
EMSL Project ID:
Analysis Date: 10/16/2001

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ-5	# Structure 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
01 030106348-0001	1215.00	0.0750	0	None Detected			0.0042	<13.33	<0.0042	
02 030106348-0002	1215.00	0.0750	0	None Detected			0.0042	<13.33	<0.0042	
03 030106348-0003	1215.00	0.0750	0	None Detected			0.0042	<13.33	<0.0042	
04 030106348-0004	1215.00	0.0750	0	None Detected			0.0042	<13.33	<0.0042	
05 030106348-0005	1215.00	0.0750	28	None Detected			0.0042	<13.33	<0.0042	
06 030106348-0006	1215.00	0.0750	28	None Detected			0.0042	<13.33	<0.0042	
07 030106348-0007	1215.00	0.0750	23	None Detected			0.0042	<13.33	<0.0042	
08 030106348-0008	1215.00	0.0750	0	None Detected			0.0042	<13.33	<0.0042	

George William
Analyst

Laboratory Manager
or other approved signatory

Disclaimer: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analyst accuracy and precision) is available upon request.
Accredited for NVLAP PLM/TEM #101048-0, NY State ELAP #11508

CITY_21MC100_010318602
NYC-WTC_000420380