ambient group inc.

Indoor environmental quality surveys
Water treatment consulting
Asbestos & lead field services
Regulatory compliance programs
Air, water & solid analytical laboratories

55 West 39th Street, 12th Floor
New York, NY 10018
TEL: (212) 944-4615
FAX: (212) 944-4618
WEB: www.ambientgroup.com

April 1, 2005

Mr. Rajappan Radhakrishnan, Director
New York City Dept. of Environmental Protection
Bureau of Air, Noise, and Hazardous Materials
Asbestos and Lead Control Program
59-17 Junction Blvd. 8th floor
Flushing, NY 11373

Re: 4 Albany Street, Phase IV Work Area (Roof)
Ambient Project #01636

Dear Mr. Radhakrishnan:

As a result of abatement work performed at the above referenced location as of April 1, 2005 asbestos containing material (ACM) in the designated work areas have been removed in accordance with NYCDEP regulations NYCRR Title 15 Chapter 1 (TRU# 1486MN/04, VAR# 2391MN/04).

Samples collected during the abatement procedures all indicated an average asbestos structure concentration of less than 70 asbestos structures per square millimeter. Further, our visual inspection of the roof areas has revealed no visible ACM or ACW bags or debris, and there is no visual evidence of any remaining foam materials or viscous liquid. The air sample results coupled with the visual inspection establishes that these work areas can be broken down and released from 'containment'. Attached please find copies of the laboratory data sheets for the air samples analyzed. Please provide us with the Department's approval to release this work area from containment.

Sincerely,
Signed for Ambient Group, Inc. by

John J. Leitner
Vice President

Cc: Mike Campell (RJLG); Mark Hopper (TC); Pat Evangelista (EPA); James Dyson (DB)