NYC 9/11 Public Portal Document

AMBIENT GROUP, INC.

10 Morris Avenue, Glen Cove, NY 11542
Phone: (516) 671-2370 - Fax: (516) 609-8271
NY ELAP ID#10865

Airborne Asbestos Fiber Analysis by Transmission Electron Microscopy

Client: Lower Manhattan Development Corp.
Address: One Liberty Plaza, 20th Floor
New York, NY 10006

Collected By: Rotimi Adeola
Collected: 01/10/2005 6:03
Rotometer: Standard

Job Number: 2043
Date Received: 01/11/2005
Date Analyzed: 01/17/2005
Job Location: 130 Liberty Street

Lab ID / Field ID	Sample Location	Start/ Stop	Flow	Volume (liters)	Asbestos Type(s)	Asbestos Structures ≥.5µm <5µm	Asbestos Structures ≥ 5µm	Non-Asbestos	Analytical Sensitivity (AS/cc)	Asbestos Concentration (AS/cc)	Asbestos Concentration (AS/mm2)
0013860-001 25270-7	Washington Street/ Albany Street	6:03 14:03	4	1920	None Detected	0	0	0	0.0008	<0.0008	<3.98
0013860-002 25270-8	Albany Street/ Greenwich Street	6:12 14:13	4	1924	None Detected	0	0	0	0.0008	<0.0008	<3.98
0013860-003 25270-9	Greenwich Street	6:17 14:19	4	1928	None Detected	0	0	0	0.0008	<0.0008	<3.98
0013860-004 25270-10	Liberty Street	6:21 14:24	4	1932	None Detected	0	0	0	0.0008	<0.0008	<3.98
0013860-005 25270-11	Washington Street/ Cedar Street	6:32 14:36	4	1936	None Detected	0	0	0	0.0008	<0.0008	<3.98

SIGNED FOR AMBIENT GROUP, INC. BY:

Disclaimers: The laboratory is not responsible for fibers counted in fibers/cc which is dependent on volume collected by non-laboratory personnel.
This report may not be duplicated in part without written permission by Ambient Group, Inc. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.
This report relates only to the samples listed above.

CITY_DEP_WORBY_CANNATA_SUBP_000077273

NYC-WTC_000424944

NYC 9/11 Public Portal Document

AMBIENT GROUP, INC.

10 Morris Avenue, Glen Cove, NY 11542
Phone: (516) 671-2370 - Fax: (516) 609-8271
NY ELAP ID#10865

Airborne Asbestos Fiber Analysis by Transmission Electron Microscopy

Client: Lower Manhattan Development Corp.
Address: One Liberty Plaza, 20th Floor
New York, NY 10006

Collected By: Ike Onyenyili
Collected: 01/10/2005 14:03
Rotometer: Standard

Job Number: 2043
Date Received: 01/11/2005
Date Analyzed: 01/17/2005
Job Location: 130 Liberty Street

Lab ID / Field ID	Sample Location	Start/ Stop	Flow	Volume (liters)	Asbestos Type(s)	Asbestos Structures ≥.5µm <5µm	Asbestos Structures ≥ 5µm	Non-Asbestos	Analytical Sensitivity (AS/cc)	Asbestos Concentration (AS/cc)	Asbestos Concentration (AS/mm2)
0013861-001 25288-7	Washington Street/ Albany Street	14:03 22:03	4	1920	None Detected	0	0	0	0.0008	<0.0008	<3.98
0013861-002 25288-8	Albany Street/ Greenwich Street	14:13 22:14	4	1924	None Detected	0	0	0	0.0008	<0.0008	<3.98
0013861-003 25288-9	Greenwich Street	14:19 22:21	4	1928	None Detected	0	0	0	0.0008	<0.0008	<3.98
0013861-004 25288-10	Liberty Street	14:24 22:27	4	1932	None Detected	0	0	0	0.0008	<0.0008	<3.98
0013861-005 25288-11	Washington Street/ Cedar Street	14:36 22:40	4	1936	None Detected	0	0	0	0.0008	<0.0008	<3.98

SIGNED FOR AMBIENT GROUP, INC. BY:

Disclaimers: The laboratory is not responsible for fibers counted in fibers/cc which is dependent on volume collected by non-laboratory personnel.
This report may not be duplicated in part without written permission by Ambient Group, Inc. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.
This report relates only to the samples listed above.

CITY_DEP_WORBY_CANNATA_SUBP_000077274

NYC-WTC_000424945

NYC 9/11 Public Portal Document

AMBIENT GROUP, INC.

10 Morris Avenue, Glen Cove, NY 11542
Phone: (516) 671-2370 - Fax: (516) 609-8271
NY ELAP ID#10865

Airborne Asbestos Fiber Analysis by Transmission Electron Microscopy

Client: Lower Manhattan Development Corp.
Address: One Liberty Plaza, 20th Floor
New York, NY 10006

Collected By: Ike Onyenyili
Collected: 01/10/2005 22:03
Rotometer: Standard

Job Number: 2043
Date Received: 01/11/2005
Date Analyzed: 01/17/2005
Job Location: 130 Liberty Street

Lab ID / Field ID	Sample Location	Start/ Stop	Flow	Volume (liters)	Asbestos Type(s)	Asbestos Structures ≥ .5µm <5µm	Asbestos Structures ≥ 5µm	Non-Asbestos	Analytical Sensitivity (AS/cc)	Asbestos Concentration (AS/cc)	Asbestos Concentration (AS/mm2)
0013862-001 25289-7	Washington Street/ Albany Street	22:03 6:02	4	1916	None Detected	0	0	0	0.0008	<0.0008	<3.98
0013862-002 25289-8	Albany Street/ Greenwich Street	22:14 6:08	4	1896	None Detected	0	0	0	0.0008	<0.0008	<3.79
0013862-003 25289-9	Greenwich Street	22:21 6:14	4	1892	None Detected	0	0	0	0.0008	<0.0008	<3.79
0013862-004 25289-10	Liberty Street	22:27 6:21	4	1896	None Detected	0	0	0	0.0008	<0.0008	<3.79
0013862-005 25289-11	Washington Street/ Cedar Street	22:40 6:30	4	1880	None Detected	0	0	0	0.0008	<0.0008	<3.79

Average Filter Loading: <3.98

SIGNED FOR AMBIENT GROUP, INC. BY:

Disclaimers: The laboratory is not responsible for fibers counted in fibers/cc which is dependent on volume collected by non-laboratory personnel.
This report may not be duplicated in part without written permission by Ambient Group, Inc. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.
This report relates only to the samples listed above.

CITY_DEP_WORBY_CANNATA_SUBP_000077275

NYC-WTC_000424946