NYC 9/11 Public Portal Document

ATHENICA
ENVIRONMENTAL SERVICES INC.
Tel: (718) 784-7490
Fax (718) 784-4085

CLIENT: SCA | SITE: Economics H.S. M
PROJECT NO. (ATHENICA FILE#): 01-0613 | DATE: 11/25/01
PURPOSE OF MONITORING: AREA SAMPLING | TECHNICIAN: G. Lopez, J. Baroutsos
CASETTE SIZE: 25 mm | LOT#: | ROTOMETER#: GL-001 | BATCH#: 01-11-085
TYPE-OF-RESPIRATOR: | PROJECT MANAGER: B. Belos
AREAS OF ABATEMENT: 3rd and 2nd Floors | TYPE-OF-REMOVAL: Dust Control

PCM [✓] TEM [ ] CHECK ONLY ONE BOX

Background [ ] Pre-Abatement [ ] Durrings [ ] Finals [✓] Others (Explain) [ ] (CHECK ONLY ONE BOX)

SAMPLE ID#	LOCATION	TYPE	PUMP	TIME IN	TIME OUT	TOTAL MIN.	FLOW BEFORE	FLOW AFTER	FLOW AVERAGE	VOLUME	FIBERS/ FIELD	FIBERS/ C.C.
	3rd Fl											
25	In Rm # 308	IFNL		1153	1323	90	14	14	14	1260	05/100	<.01
26	3rd Fl In Rm # 309			1154	1324	90	14	14	14	1260	7.5/100	<.01
27	3rd Fl Corridor SE Side			1156	1326	90	14	14	14	1260	02/100	<.01
28	2nd Fl. Auditorium Balcony Center			1440	1610	90	14	14	14	1260	11/100	<.01
29	2nd Fl Stairway A			1441	1611	90	14	14	14	1260	04/100	<.01
30	Corridor by Stairway A			1442	1612	90	14	14	14	1260	06/100	<.01
31	In Rm #207 Center			1443	1613	90	14	14	14	1260	09/100	<.01
32	#206			1444	1614	90	14	14	14	1260	03/100	<.01
33	#205			1445	1615	90	14	14	14	1260	04/100	<.01
34	#204			1446	1616	90	14	14	14	1260	2.5/100	<.01
35	#203			1448	1618	90	14	14	14	1260	08/100	<.01
36	2nd Fl Corridor by Elevator			1449	1619	90	14	14	14	1260	07/100	<.01

BGA - Backround | IWA - Inside Work Area | ICR - Inside Clean Room | OWA - Outside work area | OFNL Outside Finals
PRE - Preabatement | OB - Outside Building | NGAE - Negative Air Exhaust | OTH - Other | IFNL - Inside Finals

CHAIN OF CUSTODY RECORD

RELINQUISHED BY:	[signature]	DATE:	11/25/01	TIME:	19:30
RECEIVED BY:	[signature]	DATE:	11/25/01	TIME:	19:30
ANALYST:	[signature]	DATE:	11/25/01	TIME:	20:10

LABORATORY ACCREDITATION :
NVLAP# 101958 ELAP# 10955 METHOD : NIOSH 7400

WHITE-FILE/LAB YELLOW-CLIENT/REPORT PINK-FIELD

11/25/2001 21:03 FAX 718 784 4085 CITY_21MC100_0003076553

NYC-WTC_000429481

NYC 9/11 Public Portal Document

ATHENICA
ENVIRONMENTAL SERVICES INC.
Tel: (718) 784-7490
Fax: (718) 784-4085

PCM [✓] TEM [ ]
CHECK ONLY ONE BOX

CLIENT: SCA
SITE: Economos HS. M
PROJECT NO. (ATHENICA FILE#): 01-068
DATE: 11/25/01
PURPOSE OF MONITORING: AREA SAMPLING
TECHNICIAN: Glopez / S. Garoutsos
CASETTE SIZE: 25 mm
LOT#:
ROTOMETER#: GL-001
BATCH#: 01-11-085
TYPE-OF-RESPIRATOR:
PROJECT MANAGER: B. Bella
AREAS OF ABATEMENT: ~~Isolated~~ 1st Floors
TYPE-OF-REMOVAL: Dust Control

Background [ ] Pre-Abatement [ ] Durrings [ ] Finals [✓] Others (Explain) [ ]
(CHECK ONLY ONE BOX)

SAMPLE ID#	LOCATION	TYPE *	PUMP	TIME IN	TIME OUT	TOTAL MIN.	FLOW BEFORE	FLOW AFTER	FLOW AVERAGE	VOLUME	FIBERS/ FIELD	FIBERS/ C.C.
37	1st Fl Lobby by Mens Rm	IFNL		1453	1623	90	14	14	14	1260	03/100	<.01
38	" in Rm #105 Center	"		1454	1624	90	14	14	14	1260	05/100	<.01
39	" " #104 Center	"		1455	1625	90	14	14	14	1260	2.5/100	<.01
40	1st Fl Lobby Center	"		1456	1626	90	14	14	14	1260	08/100	<.01
41	" in Rm #104A Center	"		1457	1627	90	14	14	14	1260	02/100	<.01
42	" " #102 Center	"		1458	1628	90	14	14	14	1260	07/100	<.01
43	1st Fl Auditorium Center	"		1500	1630	90	14	14	14	1260	03/100	<.01
44	FB										00/100	
45	FB										00/100	
46	FB										00/100	
47	FB										00/100	

BGA - Backround
PRE - Preabatement
IWA - Inside Work Area
OB - Outside Building
ICR - Inside Clean Room
NGAE - Negative Air Exhaust
OWA - Outside work area
OTH - Other
OFNL Outside Finals
IFNL - Inside Finals

CHAIN OF CUSTODY RECORD

RELINQUISHED BY :	Lopez	DATE :	11/25/01	TIME :	19:30
RECEIVED BY :		DATE :	11/25/01	TIME :	19:30
ANALYST :		DATE :	11/25/01	TIME :	20:10

LABORATORY ACCREDITATION :
NVLAP# 101958 ELAP# 10955 METHOD : NIOSH 7400

WHITE-FILE/LAB YELLOW-CLIENT/REPORT PINK-FIELD

11/25/2001 21:03 FAX 718 784 4085 CITY_21MC100_00307655 4

NYC-WTC_000429482