NYC 9/11 Public Portal Document

EMSL Analytical, Inc.
208 Stone Hinge Lane, Carle Place, NY 11514
Phone: 516-997-7251 Fax: 5169977528 Email: carleplacelab@emsl.com

Attn: Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001
Fax: (516) 358-1780 Phone: 516-358-2955
Project: **PS234M**

Customer ID: TAYL50
Customer PO:
Received: 10/23/02 8:33 PM
EMSL Order: 060212591
EMSL Project ID:
Analysis Date 10/24/2002

Asbestos Analysis of Non-Friable Organically Bound Materials by PLM via the NY State ELAP 198.1 Method

SAMPLE ID	DESCRIPTION	APPEARANCE	% MATRIX MATERIAL	% NON-ASBESTOS FIBERS	ASBESTOS TYPES	% TOTAL ASBESTOS
15503-01 *060212591-0001*	LIBRARY CARPET BACKING MASTIC	Non-Fibrous Homogeneous	100.0	None	Inconclusive: No Asbestos Detected	
15504-02 *060212591-0002*	LIBRARY CARPET BACKING MASTIC	Non-Fibrous Homogeneous	100.0	None	Inconclusive: No Asbestos Detected	
15505-03 *060212591-0003*	LIBRARY CARPET BACKING MASTIC	Non-Fibrous Homogeneous	100.0	None	Inconclusive: No Asbestos Detected	

Fahrudin Lalic
Analyst

Michelle McGowan
or other approved signatory

Polarized Light Microscopy is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. Quantitative transmission electron microscopy is currently the only method that can be used to determine if this material can be considered or treated as non-asbestos containing. The above report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL Analytical, Inc. The above test must not be used to claim product endorsement by NVLAP nor any agency of the United States Government.

NYPNOB2

CONFIDENTIAL, CITY_21MC100_003474732
SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008
NYC-WTC_000430723