NYC 9/11 Public Portal Document

EMSL Analytical, Inc.
208 Stone Hinge Lane, Carle Place, NY 11514
Phone: 516-997-7251 Fax: 5169977528 Email: carleplacelab@emsl.com

Attn: Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001
Fax: (516) 358-1780 Phone: 516-358-2955
Project: **PS234M**

Customer ID: TAYL50
Customer PO:
Received: 10/23/02 8:33 PM
EMSL Order: 060212591
EMSL Project ID:
Analysis Date 10/24/2002

Asbestos Analysis of Non-Friable Organically Bound materials by Transmission Electron Microscopy via NYS ELAP Method 198.4

SAMPLE ID	DESCRIPTION	APPEARANCE	% MATRIX MATERIAL	% NON-ASBESTOS	ASBESTOS TYPES	% TOTAL ASBESTOS
15503-01 060212591-0001	LIBRARY CARPET BACKING MASTIC	Non-Fibrous Homogeneous	100.0	None	No Asbestos Detected	
15504-02 060212591-0002	LIBRARY CARPET BACKING MASTIC	Non-Fibrous Homogeneous	100.0	None	No Asbestos Detected	
15505-03 060212591-0003	LIBRARY CARPET BACKING MASTIC	Non-Fibrous Homogeneous	100.0	None	No Asbestos Detected	

Joanna Lacey
Analyst

Michelle McGowan
or other approved signatory

This laboratory is not responsible for % asbestos in total sample when the residue only is submitted for analysis. The above report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL Analytical, Inc.
ACCREDITATIONS: AIHA #102344, NVLAP #101048-10 and NY STATE ELAP #11469

NYTJOB-2

CONFIDENTIAL, CITY_21MC100_003474733
SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008
NYC-WTC_000430724