NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 07-16-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
345 Chambers St., NY

SAMPLED BY: Client

SAMPLE DATE 07-15-02
DATE RECEIVED: 07-15-02
DATE ANALYZED: 07-15-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu g/ft^2$)	DETECTION LIMIT ($\mu g/ft^2$)
LW-01	20386	Rm 1009 South Side Left Univent - Rear	<9.0	9.0
LW-02	20386	Rm 1009 South Side Right Univent - Rear	<9.0	9.0
LW-03	20386	Rm 1017 South Side Left Univent - Rear	<9.0	9.0
LW-04	20386	Rm 1017 South Side Right Univent - Rear	<9.0	9.0
LW-05	20386	Rm 1025 South Side Left Univent - Rear	<9.0	9.0
LW-06	20386	Rm 1025 South Side Middle Univent - Rear	<9.0	9.0
LW-07	20386	Rm 1025 South Side Right Side - Rear	<9.0	9.0
LW-08	20386	Rm 1024 North Side Left Univent - Rear	<9.0	9.0
LW-09	20386	Rm 1024 North Side Right Univent - Rear	<9.0	9.0
LW-10	20386	Rm 1033 South Side Left Univent - Rear	<9.0	9.0
LW-11	20386	Rm 1033 South Side Right Univent - Rear	<9.0	9.0
LW-12	20386	Rm 1039 South Side - Rear	<9.0	9.0
LW-13	20386	Rm 1039 North Side Left Univent - Rear	11.3	9.0
LW-14	20386	Rm 1039 North Side Middle Univent - Rear	<9.0	9.0
LW-15	20386	Rm 1039 North Side Right Univent - Rear	<9.0	9.0
FBL-1	20386	Field Blank	<9.0 µg	9.0 µg
FBL-2	20386	Field Blank	<9.0 µg	9.0 µg

NYC-WTC_000430818

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

NOTE 1:
THE REPORTING LIMIT (RL) IS 18.0 µg
NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft², Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².
NOTE 3:
Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: [signature]

REPORT PREPARED BY: [signature]

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: [signature]

LABORATORY DIRECTOR: [signature]

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC-WTC_000430819