NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 07-18-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
345 Chambers St., NY

SAMPLED BY: Client

SAMPLE DATE 07-17-02
DATE RECEIVED: 07-17-02
DATE ANALYZED: 07-17-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu g/ft^2$)	DETECTION LIMIT ($\mu g/ft^2$)
LW-01	20445	Rm 1010 Left Side Univent Back Wall	11.1	9.0
LW-02	20445	Rm 1010 Center Univent Back Wall	19.1	9.0
LW-03	20445	Rm 1010 Right Side Univent Back Wall	11.7	9.0
FB1	20445	Field Blank	<9.0 µg	9.0 µg
FB2	20445	Field Blank	<9.0 µg	9.0 µg

NOTE 1:
THE REPORTING LIMIT (RL) IS 18.0 µg
NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu g/ft^2$, Window sills 250 $\mu g/ft^2$, Window wells 400 $\mu g/ft^2$, Exterior surfaces 800 $\mu g/ft^2$.
NOTE 3:
Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).