NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE:	07-25-02
CLIENT:	Taylor Environmental Group, Inc.
PROJECT NAME:	SCA/Stuyvesant HS 345 Chambers Street, NY
PROJECT NUMBER:	M477-15217/29881
SAMPLED BY:	Client
SAMPLE DATE:	07-24-02
DATE RECEIVED:	07-24-02
DATE ANALYZED:	07-24-02
SAMPLE MEDIA:	Dust Wipe Sample
ANALYSIS REQUIRED:	Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu g/ft^2$)	DETECTION LIMIT ($\mu g/ft^2$)
01	20614	Library/615 East Side Rear Unitvent	<9.0	9.0
02	20614	Library/315 A Rear Unitvent	24.4	9.0
03	20614	Rm 525 Left Unitvent	22.3	9.0
04	20614	Rm 525 Right Unitvent	21.2	9.0
05	20614	Rm 513 Left	32.5	9.0
06	20614	Rm 513 Right	<9.0	9.0
07	20614	Rm 513 Left	15.1	9.0
08	20614	Rm 513 Right	<9.0	9.0
09	20614	Rm 501C Unitvent	<9.0	9.0
10	20614	Rm 501B Unitvent	13.9	9.0
11	20614	Rm 508 Unitvent Left	13.3	9.0
12	20614	Rn 508 Unitvent Right	20.3	9.0
13	20614	Rm 531 Unitvent Right	<9.0	9.0
14	20614	Rm 531 Unitvent Center	<9.0	9.0
15	20614	Rm 531 Unitvent Left	<9.0	9.0

NYC-WTC_000430876

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

NOTE 1:
THE REPORTING LIMIT (RL) IS 18.0 µg
NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft², Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².
NOTE 3:
Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: HCU

REPORT PREPARED BY:

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR:

LABORATORY DIRECTOR:

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).