NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE:	07-29-02
CLIENT:	Taylor Environmental Group, Inc.
PROJECT NAME:	SCA/Stuyvesant HS 345 Chambers Street, NY
PROJECT NUMBER:	M477-15217/29881
SAMPLED BY:	Client
SAMPLE DATE:	07-27-02
DATE RECEIVED:	07-27-02
DATE ANALYZED:	07-27-02
SAMPLE MEDIA:	Dust Wipe Sample
ANALYSIS REQUIRED:	Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu g/ft^2$)	DETECTION LIMIT ($\mu g/ft^2$)
LW-01	20698	Rm 907 Ceiling Unitvent Damper	<9.0	9.0
FBL-1	20698	Field Blank	<9.0 µg	9.0 µg
FBL-2	20698	Field Blank	<9.0 µg	9.0 µg

NOTE 1:
THE REPORTING LIMIT (RL) IS 18.0 µg
NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu g/ft^2$, Window sills 250 $\mu g/ft^2$, Window wells 400 $\mu g/ft^2$, Exterior surfaces 800 $\mu g/ft^2$.
NOTE 3:
Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: RD

REPORT PREPARED BY:

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR:

LABORATORY DIRECTOR:

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).