NYC 9/11 Public Portal Document


# ATC ASSOCIATES, INC
**104 E 25th Street, 10th Floor**
**New York, NY 10010**
**Tel. 212-353-8280**
**Fax 212-353-8306**


| | |
|---|---|
| **REPORT DATE:** | 08-09-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>345 Chambers Street, NY |
| **PROJECT NUMBER:** | M477-15217-29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE:** | 08-08-02 |
| **DATE RECEIVED:** | 08-09-02 |
| **DATE ANALYZED:** | 08-09-02 |
| **SAMPLE MEDIA:** | Dust Wipe Sample |
| **ANALYSIS REQUIRED:** | Method EPA 3050/7420 |

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/ft^2$) | DETECTION LIMIT ($\mu g/ft^2$) |
|---|---|---|---|---|
| LW-01 | 21024 | Rm 273C Ceiling Unitvent Damper | <9.0 | 9.0 |
| LW-02 | 21024 | Rm 250 Wall/Floor (Left) Unitvent Rear | <9.0 | 9.0 |
| LW-03 | 21024 | Rm 250 Ceiling Unitvent Damper | <9.0 | 9.0 |
| LW-04 | 21024 | Rm 251 Ceiling Unitvent Damper | <9.0 | 9.0 |
| FBL-1 | 21024 | Field Blank | <9.0 µg | 9.0 µg |
| FBL-2 | 21023 | Field Blank | <9.0 µg | 9.0 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 18.0 µg**
NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu g/ft^2$, Window sills 250 $\mu g/ft^2$, Window wells 400 $\mu g/ft^2$, Exterior surfaces 800 $\mu g/ft^2$.
NOTE 3:
Blank units are in µg



NYC-WTC_000430950

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).



NYC-WTC_000430951