NYC 9/11 Public Portal Document

FROM:
LEMPERT, ALEX

TO:
Orlan,Bernard

DATE:
07/31/2002 06:01:29 PM

SUBJECT:
FW: Stuyvesant High School

Bernie:

On 7/17/02 and 7/24/02 ambient air samples were collected outside the tent enclosures in room # 911
(9th floor-7.17.02) and room # 403 (4th floor-7/24/02) and analyzed for lead via NIOSH method 7082.

Results:
Room # 911.....15.5 ug/m3
Room # 403.....16.7 ug/m3

This data was evaluated in conjunction with the personal (OSHA) monitoring being conducted at the
same time on personel working within the tent enclosure(s).

Results;
Inside tent Room # 911.....<6.4 & <5.7 ug/m3
Inside tent Room # 403..... <4.2 & 7.5 ug/m3

As the results of samples collected within the tents are significantly lower than the samples collected outside the tents, this would indicate that the tent enclosures are operating effectively .

NYC-WTC_000434819