NYC 9/11 Public Portal Document

City of New York **Department of Design and Construction**

MEMORANDUM

November 20, 2001

TO: Michael Burton, PE
Executive Deputy Commissioner

FROM: Robert C. Adams, CIH, CSP
Director EHS Services

RE: Air Sampling Report – AMEX 30th Floor

Warren & Panzer Engineers collected air samples on the 30th floor of the American Express Building on Saturday evening November 17 and Sunday November 18, 2001. The samples were submitted to ATC Associates analytical laboratory for analysis by transmission electron microscopy (TEM), an analytical method that specifically identifies the presence of asbestos fibers. The results of this first round of sampling are attached. None of the three samples collected revealed the presence of asbestos fibers.

Contact me if you have any questions.

CC: Gina Betro; Bill Cote

t:\americanexpress\acmsamplingmemo_amex30_11-20-01.doc