NYC 9/11 Public Portal Document

P.02

ENVIRO-PROBE, INC.
3830 PARK AVENUE
EDISON, N.J. 08820
(732) 494-4600

ASBESTOS FIBER AIR ANALYSES RESULTS

TRANSMISSION ELECTRON MICROSCOPY

CLIENT NAME: River Point Inc
CLIENT FILE #: 101121
CLIENT ADRESS: 7 Hillside Ave
CITY, STATE: New Rochelle NY 10801

LAB FILE #: AQ1-95
DATE RECEIVED: 10-27-01
DATE REPORTED: 10-27-01

Please find below the results of analyses of the filters submitted for Transmission Electron Microscopy.
(NIOSH 7402 TEST METHOD)

THE AIR SAMPLES WERE NOT COLLECTED BY ENVIRO-PROBE, INC.

The asbestos airborne results were calculated for the client based upon the air sampling information provided by the client.

TYPE OF TEST: AIR

LOCATION	SAMPLE # LAB ID	SAMPLE # CLIENT ID	VOLUME (Liters)	ASBESTOS TYPE	TOTAL # of FIBERS COUNTED	Fibers/cc	ANALYTICAL SENSITIVITY
	E01-1364	C51026	652.5	ND	—	<0.006	0.006
	E01-1365	201026	652.5	ND	—	<0.006	0.006

Ved P. Kukreja, Ph.D
Lab Director

Oct-27-01 02:39P Ved P. Kukreja, Ph.D.

CITY_21MC100_00892078

NYC-WTC_000437005