Table 2d
Asbestos Microvac (ASTM 5575)
Ceiling Tiles
New York City Law Department
100 Church Street
New York

* Sample ID :		MV2006	MV2007	MV2001	MV2002
Lab Sample ID :		6	7	1	2
Sample Date :		8/9/2002	8/9/2002	8/13/2002	8/13/2002
* Sample Type :	Geometric	Microvac	Microvac	Microvac	Microvac
Floor:	Mean	20	20	20	20
Surface Type:		Ceiling tile	Ceiling tile	Ceiling tile	Ceiling tile
Location:		In front of west main door	G. Knowles 8-1460 Northeast corner office	T. Longo Northwest Room 8-1677	South corridor at lobby area
CONSTITUENTS					
ASBESTOS (structures/cm^2)	**17,349**	9,630	**32,100**	8,560	**34,240**

* Post Cleaning Target = <10,000 str/cm^2 (structures per square centimeter) individual sample and geometric mean of <1,000 str/cm^2

CITY_21MC100_00487951O

TRC
Customer-Focused Solutions